

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P244943

Luminaire Tested: **LSR8B50D010 EC8B509727 8LBS0WMH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P244943
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-14)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B50D010 EC8B509727 8LBS0WMH
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
97 CRI 2700 CCT WITH WARM HAZE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4120.0 lumens
Efficiency: N/A
Efficacy: 77.7 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.25
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 53
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P244943

CATALOG NUMBER: LSR8B50D010 EC8B509727 8LBS0WMH

Luminous Intensity Polar Plot





TEST NUMBER: P244943

CATALOG NUMBER: LSR8B50D010 EC8B509727 8LBS0WMH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	109	106	103	110	107	104	101	102	100	98		99	97	95		95	94	92	91
2	105	99	94	89	102	97	92	88	94	90	86		90	87	85		88	85	83	81
3	98	90	83	78	95	88	82	78	85	80	76		83	79	75		80	77	74	72
4	91	82	75	69	89	80	74	69	78	72	68		76	71	67		74	70	66	65
5	85	74	67	62	83	73	67	61	71	65	61		70	64	60		68	63	60	58
6	79	68	61	55	77	67	60	55	66	59	55		64	58	54		63	58	54	52
7	74	63	55	50	72	62	55	50	60	54	49		59	53	49		58	53	49	47
8	69	58	50	45	68	57	50	45	56	49	45		55	49	45		54	48	45	43
9	65	53	46	41	64	53	46	41	52	45	41		51	45	41		50	45	41	39
10	61	50	43	38	60	49	42	38	48	42	38		47	42	38		46	41	37	36

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P244943

CATALOG NUMBER: LSR8B50D010 EC8B509727 8LBS0WMH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	219.9	5.3
10°-20°	622.5	15.1
20°-30°	926.7	22.5
30°-40°	1052.7	25.6
40°-50°	860.5	20.9
50°-60°	337.2	8.2
60°-70°	78.6	1.9
70°-80°	18.9	0.5
80°-90°	3.0	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1769.1	42.9
0°-40°	2821.8	68.5
0°-60°	4019.5	97.6
0°-90°	4120.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4120.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2336	
5°	2320	220
15°	2207	622
25°	2016	927
35°	1692	1053
45°	1143	860
55°	351	337
65°	73	79
75°	17	19
85°	2	3
90°	0	



TEST NUMBER: P244943

CATALOG NUMBER: LSR8B50D010 EC8B509727 8LBS0WMH

CANDELA DISTRIBUTION (FULL):

	0°
0°	2336.0
2.5°	2332.3
5°	2319.9
7.5°	2298.8
10°	2272.8
12.5°	2240.6
15°	2207.1
17.5°	2167.4
20°	2124.1
22.5°	2073.3
25°	2016.3
27.5°	1949.3
30°	1873.7
32.5°	1788.2
35°	1691.6
37.5°	1585.0
40°	1466.0
42.5°	1322.3
45°	1142.6
47.5°	931.9
50°	712.6
52.5°	511.8
55°	350.7
57.5°	229.3
60°	153.7
62.5°	105.3
65°	73.1
67.5°	48.3
70°	32.2
72.5°	22.3
75°	17.3
77.5°	12.4
80°	7.4
82.5°	3.7
85°	2.5
87.5°	1.2
90°	0.0

(END OF REPORT)