

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P246992

Luminaire Tested: **LSR8B100D010 EC8B100927 8LBM0LI**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P246992
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-81)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B100D010 EC8B100927 8LBMOLI
Description: PORTFOLIO 8 INCH MEDIUM DISTRIBUTION 55 DEG CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
97 CRI 2700 CCT WITH SPECULAR CLEAR TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 8755.8 lumens
Efficiency: N/A
Efficacy: 82.4 lumens/watt
Spacing Criteria (0/90/45): 0.67 / 0.67 / 0.75
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 106.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P246992

CATALOG NUMBER: LSR8B100D010 EC8B100927 8LBM0LI

Luminous Intensity Polar Plot





TEST NUMBER: P246992

CATALOG NUMBER: LSR8B100D010 EC8B100927 8LBM0LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100
1	114	111	109	107	111	109	107	105	105	103	102	101	100	99	98	97	96	94	94	94
2	109	104	100	97	107	102	99	96	99	96	94	96	94	92	94	92	90	88	88	88
3	104	98	93	89	102	96	92	89	94	90	87	91	88	86	89	87	85	83	83	83
4	99	92	87	83	97	91	86	82	89	85	81	87	83	80	85	82	79	78	78	78
5	94	87	81	77	93	86	81	77	84	79	76	82	78	75	81	77	75	73	73	73
6	90	82	76	72	89	81	76	72	79	75	71	78	74	71	77	73	70	69	69	69
7	86	77	72	68	85	77	71	68	75	71	67	74	70	67	73	69	67	65	65	65
8	82	73	68	64	81	73	67	64	72	67	63	71	66	63	70	66	63	62	62	62
9	79	70	64	60	78	69	64	60	68	63	60	67	63	60	67	63	60	58	58	58
10	75	66	61	57	74	66	61	57	65	60	57	64	60	57	64	60	57	55	55	55

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P246992

CATALOG NUMBER: LSR8B100D010 EC8B100927 8LBM0LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1252.3	14.3
10°-20°	2745.3	31.4
20°-30°	2799.7	32.0
30°-40°	1568.0	17.9
40°-50°	334.4	3.8
50°-60°	41.4	0.5
60°-70°	10.8	0.1
70°-80°	2.5	0.0
80°-90°	1.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	6797.3	77.6
0°-40°	8365.3	95.5
0°-60°	8741.1	99.8
0°-90°	8755.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8755.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14369	
5°	13717	###
15°	9884	2745
25°	6172	2800
35°	2486	1568
45°	372	334
55°	32	41
65°	12	11
75°	4	3
85°	4	1
90°	0	



TEST NUMBER: P246992

CATALOG NUMBER: LSR8B100D010 EC8B100927 8LBM0LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	14368.7
2.5°	14206.8
5°	13717.2
7.5°	12929.4
10°	11957.3
12.5°	10914.0
15°	9883.8
17.5°	8847.6
20°	7894.8
22.5°	7008.2
25°	6171.5
27.5°	5293.1
30°	4365.8
32.5°	3396.7
35°	2485.7
37.5°	1665.3
40°	1035.2
42.5°	618.9
45°	371.6
47.5°	206.7
50°	121.2
52.5°	64.1
55°	31.5
57.5°	22.4
60°	19.3
62.5°	9.1
65°	12.3
67.5°	12.3
70°	1.0
72.5°	3.0
75°	4.0
77.5°	2.0
80°	0.0
82.5°	1.0
85°	4.0
87.5°	0.0
90°	0.0

(END OF REPORT)