

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P246601

Luminaire Tested: **LSR8B15D010 EC8B15930 8LBW0MW**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P246601
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-48)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B15D010 EC8B15930 8LBW0MW
Description: PORTFOLIO 8 INCH WIDE DISTRIBUTION 60 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
97 CRI 3000 CCT WITH MATTE WHITE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1293.7 lumens
Efficiency: N/A
Efficacy: 89.8 lumens/watt
Spacing Criteria (0/90/45): 1.11 / 1.11 / 1.05
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P246601

CATALOG NUMBER: LSR8B15D010 EC8B15930 8LBW0MW

Luminous Intensity Polar Plot





TEST NUMBER: P246601

CATALOG NUMBER: LSR8B15D010 EC8B15930 8LBW0MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	111	107	104	101	109	105	102	99	101	99	96	97	95	93	94	92	91	89
2	103	97	91	87	101	95	90	86	92	87	84	88	85	82	86	83	80	78
3	96	88	81	76	94	86	80	75	83	78	74	81	76	73	78	75	72	70
4	90	80	73	67	88	79	72	67	76	70	66	74	69	65	72	68	64	62
5	84	73	66	60	82	72	65	60	70	64	59	68	63	59	67	62	58	56
6	79	67	60	54	77	66	59	54	65	58	54	63	58	53	62	57	53	51
7	74	62	55	49	72	61	54	49	60	54	49	59	53	49	57	52	48	47
8	69	58	50	45	68	57	50	45	56	50	45	55	49	45	54	48	45	43
9	65	54	47	42	64	53	46	42	52	46	41	51	45	41	50	45	41	40
10	62	50	43	39	61	50	43	39	49	43	38	48	42	38	47	42	38	37

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P246601

CATALOG NUMBER: LSR8B15D010 EC8B15930 8LBW0MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	79.0	6.1
10°-20°	217.5	16.8
20°-30°	319.0	24.7
30°-40°	291.6	22.5
40°-50°	144.3	11.2
50°-60°	106.7	8.3
60°-70°	82.1	6.3
70°-80°	42.8	3.3
80°-90°	10.7	0.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	615.5	47.6
0°-40°	907.1	70.1
0°-60°	1158.1	89.5
0°-90°	1293.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1293.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	857	
5°	840	79
15°	770	218
25°	698	319
35°	484	292
45°	175	144
55°	118	107
65°	84	82
75°	40	43
85°	9	11
90°	0	



TEST NUMBER: P246601

CATALOG NUMBER: LSR8B15D010 EC8B15930 8LBW0MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	857.1
2.5°	852.6
5°	839.5
7.5°	821.8
10°	803.8
12.5°	786.2
15°	770.1
17.5°	755.0
20°	738.5
22.5°	720.1
25°	698.4
27.5°	668.3
30°	626.5
32.5°	567.9
35°	483.7
37.5°	379.6
40°	280.2
42.5°	212.1
45°	175.2
47.5°	155.1
50°	140.3
52.5°	128.5
55°	118.2
57.5°	109.5
60°	102.1
62.5°	94.4
65°	83.7
67.5°	72.2
70°	60.8
72.5°	50.1
75°	39.8
77.5°	30.8
80°	22.5
82.5°	15.6
85°	9.1
87.5°	3.3
90°	0.0

(END OF REPORT)