

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P244900

Luminaire Tested: **LSR8B40D010 EC8B40840 8LBS0WMH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P244900
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-14)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B40D010 EC8B40840 8LBS0WMH
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
80 CRI 4000 CCT WITH WARM HAZE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4699.0 lumens
Efficiency: N/A
Efficacy: 114.9 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.25
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 40.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P244900

CATALOG NUMBER: LSR8B40D010 EC8B40840 8LBS0WMH

Luminous Intensity Polar Plot





TEST NUMBER: P244900

CATALOG NUMBER: LSR8B40D010 EC8B40840 8LBS0WMH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	112	109	106	103	110	107	104	101	102	100	98	99	97	95	95	94	92	91
2	105	99	94	89	102	97	92	88	94	90	86	90	87	85	88	85	83	81
3	98	90	83	78	95	88	82	78	85	80	76	83	79	75	80	77	74	72
4	91	82	75	69	89	80	74	69	78	72	68	76	71	67	74	70	66	65
5	85	74	67	62	83	73	67	61	71	65	61	70	64	60	68	63	60	58
6	79	68	61	55	77	67	60	55	66	59	55	64	58	54	63	58	54	52
7	74	63	55	50	72	62	55	50	60	54	49	59	53	49	58	53	49	47
8	69	58	50	45	68	57	50	45	56	49	45	55	49	45	54	48	45	43
9	65	53	46	41	64	53	46	41	52	45	41	51	45	41	50	45	41	39
10	61	50	43	38	60	49	42	38	48	42	38	47	42	38	46	41	37	36

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	82157
5°	81901
10°	81167
15°	80363
20°	79498
25°	78242
30°	76095
35°	72627
40°	67309
45°	56831
50°	38987
55°	21505
60°	10811
65°	6085
70°	3309
75°	2359
80°	1509
85°	991



TEST NUMBER: P244900

CATALOG NUMBER: LSR8B40D010 EC8B40840 8LBS0WMH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	250.8	5.3
10°-20°	709.9	15.1
20°-30°	1057.0	22.5
30°-40°	1200.6	25.6
40°-50°	981.4	20.9
50°-60°	384.6	8.2
60°-70°	89.6	1.9
70°-80°	21.6	0.5
80°-90°	3.4	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2017.7	42.9
0°-40°	3218.3	68.5
0°-60°	4584.3	97.6
0°-90°	4699.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4699.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2664	
5°	2646	251
15°	2517	710
25°	2300	1057
35°	1929	1201
45°	1303	981
55°	400	385
65°	83	90
75°	20	22
85°	3	3
90°	0	



TEST NUMBER: P244900

CATALOG NUMBER: LSR8B40D010 EC8B40840 8LBS0WMH

CANDELA DISTRIBUTION (FULL):

	0°
0°	2664.3
2.5°	2660.0
5°	2645.9
7.5°	2621.9
10°	2592.2
12.5°	2555.4
15°	2517.3
17.5°	2472.0
20°	2422.6
22.5°	2364.6
25°	2299.6
27.5°	2223.3
30°	2137.1
32.5°	2039.5
35°	1929.3
37.5°	1807.7
40°	1672.1
42.5°	1508.1
45°	1303.2
47.5°	1062.9
50°	812.7
52.5°	583.7
55°	400.0
57.5°	261.5
60°	175.3
62.5°	120.1
65°	83.4
67.5°	55.1
70°	36.7
72.5°	25.4
75°	19.8
77.5°	14.1
80°	8.5
82.5°	4.2
85°	2.8
87.5°	1.4
90°	0.0

(END OF REPORT)