

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P245747

Luminaire Tested: **LSR8B50D010 EC8B50827 8LBS0GPH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P245747
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-16)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B50D010 EC8B50827 8LBS0GPH
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
80 CRI 2700 CCT WITH GRAPHITE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5116.0 lumens
Efficiency: N/A
Efficacy: 96.5 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.25
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 53
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P245747

CATALOG NUMBER: LSR8B50D010 EC8B50827 8LBS0GPH

Luminous Intensity Polar Plot





TEST NUMBER: P245747

CATALOG NUMBER: LSR8B50D010 EC8B50827 8LBS0GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|-----|-----|-----|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | 0 | | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | | 50 | 30 | 10 | | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | | 106 | 106 | 106 | | 102 | 102 | 102 | 100 |
| 1 | 112 | 109 | 106 | 103 | 110 | 107 | 104 | 102 | 103 | 100 | 98 | | 99 | 97 | 95 | | 95 | 94 | 93 | 91 |
| 2 | 105 | 99 | 94 | 90 | 103 | 97 | 93 | 89 | 94 | 90 | 87 | | 91 | 88 | 85 | | 88 | 85 | 83 | 81 |
| 3 | 98 | 90 | 84 | 79 | 96 | 88 | 83 | 78 | 86 | 81 | 77 | | 83 | 79 | 76 | | 81 | 77 | 74 | 73 |
| 4 | 91 | 82 | 75 | 70 | 89 | 81 | 74 | 69 | 78 | 73 | 69 | | 76 | 72 | 68 | | 74 | 70 | 67 | 65 |
| 5 | 85 | 75 | 68 | 62 | 83 | 74 | 67 | 62 | 72 | 66 | 61 | | 70 | 65 | 61 | | 68 | 64 | 60 | 58 |
| 6 | 79 | 69 | 61 | 56 | 78 | 68 | 61 | 56 | 66 | 60 | 55 | | 64 | 59 | 55 | | 63 | 58 | 54 | 53 |
| 7 | 74 | 63 | 56 | 50 | 73 | 62 | 55 | 50 | 61 | 55 | 50 | | 59 | 54 | 50 | | 58 | 53 | 49 | 48 |
| 8 | 70 | 58 | 51 | 46 | 68 | 57 | 50 | 46 | 56 | 50 | 45 | | 55 | 49 | 45 | | 54 | 49 | 45 | 43 |
| 9 | 65 | 54 | 47 | 42 | 64 | 53 | 46 | 42 | 52 | 46 | 41 | | 51 | 45 | 41 | | 50 | 45 | 41 | 40 |
| 10 | 62 | 50 | 43 | 38 | 60 | 49 | 43 | 38 | 48 | 42 | 38 | | 48 | 42 | 38 | | 47 | 42 | 38 | 36 |

AVERAGE LUMINANCE (cd/sqm):

| | |
|-----|-------|
| | 0° |
| 0° | 90554 |
| 5° | 90278 |
| 10° | 89390 |
| 15° | 88471 |
| 20° | 87545 |
| 25° | 86112 |
| 30° | 83758 |
| 35° | 79937 |
| 40° | 74325 |
| 45° | 62758 |
| 50° | 42609 |
| 55° | 22257 |
| 60° | 9985 |
| 65° | 4874 |
| 70° | 1956 |
| 75° | 1191 |
| 80° | 888 |
| 85° | 601 |



TEST NUMBER: P245747

CATALOG NUMBER: LSR8B50D010 EC8B50827 8LBS0GPH

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 276.4 | 5.4 |
| 10°-20° | 781.7 | 15.3 |
| 20°-30° | 1163.6 | 22.7 |
| 30°-40° | 1322.8 | 25.9 |
| 40°-50° | 1081.6 | 21.1 |
| 50°-60° | 403.2 | 7.9 |
| 60°-70° | 73.7 | 1.4 |
| 70°-80° | 11.4 | 0.2 |
| 80°-90° | 1.6 | 0.0 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 2221.7 | 43.4 |
| 0°-40° | 3544.5 | 69.3 |
| 0°-60° | 5029.3 | 98.3 |
| 0°-90° | 5116.0 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 5116.0 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|------|------|
| 0° | 2937 | |
| 5° | 2916 | 276 |
| 15° | 2771 | 782 |
| 25° | 2531 | 1164 |
| 35° | 2124 | 1323 |
| 45° | 1439 | 1082 |
| 55° | 414 | 403 |
| 65° | 67 | 74 |
| 75° | 10 | 11 |
| 85° | 2 | 2 |
| 90° | 0 | |



TEST NUMBER: P245747

CATALOG NUMBER: LSR8B50D010 EC8B50827 8LBS0GPH

CANDELA DISTRIBUTION (FULL):

| | 0° |
|-------|--------|
| 0° | 2936.6 |
| 2.5° | 2931.6 |
| 5° | 2916.5 |
| 7.5° | 2889.8 |
| 10° | 2854.8 |
| 12.5° | 2814.7 |
| 15° | 2771.3 |
| 17.5° | 2721.2 |
| 20° | 2667.8 |
| 22.5° | 2604.4 |
| 25° | 2530.9 |
| 27.5° | 2447.4 |
| 30° | 2352.3 |
| 32.5° | 2243.8 |
| 35° | 2123.5 |
| 37.5° | 1995.0 |
| 40° | 1846.4 |
| 42.5° | 1662.8 |
| 45° | 1439.1 |
| 47.5° | 1170.3 |
| 50° | 888.2 |
| 52.5° | 626.0 |
| 55° | 414.0 |
| 57.5° | 260.4 |
| 60° | 161.9 |
| 62.5° | 103.5 |
| 65° | 66.8 |
| 67.5° | 38.4 |
| 70° | 21.7 |
| 72.5° | 13.4 |
| 75° | 10.0 |
| 77.5° | 6.7 |
| 80° | 5.0 |
| 82.5° | 1.7 |
| 85° | 1.7 |
| 87.5° | 0.0 |
| 90° | 0.0 |

(END OF REPORT)