

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P250833

Luminaire Tested: **LSR8B70D010 EC8B70940 8LBN0LI**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P250833
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-10)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B70D010 EC8B70940 8LBNOLI
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
90 CRI 4000 CCT WITH SPECULAR CLEAR TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6393.0 lumens
Efficiency: N/A
Efficacy: 84.2 lumens/watt
Spacing Criteria (0/90/45): 0.25 / 0.25 / 0.32
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 75.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P250833

CATALOG NUMBER: LSR8B70D010 EC8B70940 8LBNOLI

Luminous Intensity Polar Plot





TEST NUMBER: P250833

CATALOG NUMBER: LSR8B70D010 EC8B70940 8LBNOLI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	112	110	108	112	110	108	106	106	104	103		102	101	100		99	98	97	95
2	110	106	102	100	108	104	101	99	101	99	96		98	96	94		95	94	92	91
3	106	100	96	93	104	99	95	92	96	93	91		94	92	89		92	90	88	87
4	102	95	91	87	100	94	90	87	92	89	86		90	87	85		89	86	84	83
5	98	91	86	83	96	90	86	82	88	85	82		87	84	81		85	83	80	79
6	94	87	82	79	93	86	82	78	85	81	78		83	80	77		82	79	77	76
7	91	83	78	75	90	83	78	75	81	77	74		80	77	74		79	76	74	72
8	88	80	75	72	86	79	75	71	78	74	71		77	74	71		76	73	71	70
9	85	77	72	69	84	76	72	69	75	71	68		75	71	68		74	70	68	67
10	82	74	69	66	81	73	69	66	73	69	66		72	68	66		71	68	65	64

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	965837
5°	670825
10°	353002
15°	223347
20°	165980
25°	130489
30°	93948
35°	40317
40°	14053
45°	5390
50°	1247
55°	468
60°	0
65°	635
70°	198
75°	512
80°	764
85°	0



TEST NUMBER: P250833

CATALOG NUMBER: LSR8B70D010 EC8B70940 8LBNOLI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1737.4	27.2
10°-20°	2018.6	31.6
20°-30°	1742.2	27.3
30°-40°	755.8	11.8
40°-50°	118.5	1.9
50°-60°	8.6	0.1
60°-70°	4.6	0.1
70°-80°	4.8	0.1
80°-90°	2.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	5498.3	86.0
0°-40°	6254.2	97.8
0°-60°	6381.2	99.8
0°-90°	6393.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6393.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	31321	
5°	21672	###
15°	6996	2019
25°	3835	1742
35°	1071	756
45°	124	118
55°	9	9
65°	9	5
75°	4	5
85°	0	2
90°	0	



TEST NUMBER: P250833

CATALOG NUMBER: LSR8B70D010 EC8B70940 8LBNOLI

CANDELA DISTRIBUTION (FULL):

	0°
0°	31321.4
2.5°	28284.0
5°	21671.6
7.5°	15455.8
10°	11273.7
12.5°	8650.4
15°	6996.2
17.5°	5884.0
20°	5058.0
22.5°	4353.4
25°	3835.2
27.5°	3288.9
30°	2638.5
32.5°	1834.1
35°	1071.0
37.5°	598.4
40°	349.1
42.5°	216.8
45°	123.6
47.5°	99.7
50°	26.0
52.5°	13.0
55°	8.7
57.5°	4.3
60°	0.0
62.5°	2.2
65°	8.7
67.5°	6.5
70°	2.2
72.5°	10.8
75°	4.3
77.5°	0.0
80°	4.3
82.5°	2.2
85°	0.0
87.5°	4.3
90°	0.0

(END OF REPORT)