

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P250302

Luminaire Tested: **LSR8B80D010 EC8B80835 8LBN0GPH**

Issue Date: 03/03/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P250302  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P13948)  
Test Lab: INNOVATION CENTER-P1  
Issue Date: 03/03/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LSR8B80D010 EC8B80835 8LBN0GPH  
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED  
DOWNLIGHT- CYLINDEC  
80 CRI 3500 CCT WITH GRAPHITE TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 6785.0 lumens  
Efficiency: N/A  
Efficacy: 91.2 lumens/watt  
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.77  
Luminous Opening: Circular (Dia: 0.67' x H: 0')  
CIE Type: Direct


Input Watts (W): 74.4  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P250302

CATALOG NUMBER: LSR8B80D010 EC8B80835 8LBN0GPH

### Luminous Intensity Polar Plot





TEST NUMBER: P250302

CATALOG NUMBER: LSR8B80D010 EC8B80835 8LBN0GPH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |     | 30  |     |     |     | 10  | 0   |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 0   |
| RCR |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |
| 1   | 114 | 111 | 109 | 107 | 112 | 109 | 107 | 105 | 105 | 104 | 102 | 101 | 100 | 99  | 98  | 97  | 96  | 94  |
| 2   | 109 | 104 | 101 | 97  | 107 | 103 | 99  | 96  | 99  | 97  | 94  | 96  | 94  | 92  | 94  | 92  | 90  | 89  |
| 3   | 104 | 98  | 93  | 90  | 102 | 97  | 92  | 89  | 94  | 90  | 88  | 92  | 89  | 86  | 89  | 87  | 85  | 83  |
| 4   | 99  | 92  | 87  | 83  | 97  | 91  | 86  | 83  | 89  | 85  | 82  | 87  | 84  | 81  | 85  | 82  | 80  | 78  |
| 5   | 95  | 87  | 82  | 78  | 93  | 86  | 81  | 77  | 84  | 80  | 77  | 83  | 79  | 76  | 81  | 78  | 75  | 74  |
| 6   | 90  | 82  | 77  | 73  | 89  | 81  | 76  | 72  | 80  | 75  | 72  | 79  | 75  | 71  | 77  | 74  | 71  | 70  |
| 7   | 86  | 78  | 72  | 68  | 85  | 77  | 72  | 68  | 76  | 71  | 68  | 75  | 71  | 67  | 74  | 70  | 67  | 66  |
| 8   | 83  | 74  | 68  | 64  | 81  | 73  | 68  | 64  | 72  | 67  | 64  | 71  | 67  | 64  | 70  | 66  | 63  | 62  |
| 9   | 79  | 70  | 65  | 61  | 78  | 70  | 64  | 61  | 69  | 64  | 61  | 68  | 63  | 60  | 67  | 63  | 60  | 59  |
| 10  | 76  | 67  | 61  | 58  | 75  | 66  | 61  | 58  | 65  | 61  | 57  | 65  | 60  | 57  | 64  | 60  | 57  | 56  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 334321 |
| 5°  | 328977 |
| 10° | 292288 |
| 15° | 241113 |
| 20° | 203064 |
| 25° | 171274 |
| 30° | 128241 |
| 35° | 72574  |
| 40° | 28697  |
| 45° | 7706   |
| 50° | 1478   |
| 55° | 0      |
| 60° | 216    |
| 65° | 0      |
| 70° | 0      |
| 75° | 0      |
| 80° | 0      |
| 85° | 0      |



TEST NUMBER: P250302

CATALOG NUMBER: LSR8B80D010 EC8B80835 8LBN0GPH

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 973.3  | 14.3      |
| 10°-20°   | 2115.3 | 31.2      |
| 20°-30°   | 2271.0 | 33.5      |
| 30°-40°   | 1227.4 | 18.1      |
| 40°-50°   | 191.5  | 2.8       |
| 50°-60°   | 5.3    | 0.1       |
| 60°-70°   | 1.3    | 0.0       |
| 70°-80°   | 0.0    | 0.0       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 5359.6 | 79.0      |
| 0°-40°    | 6587.0 | 97.1      |
| 0°-60°    | 6783.7 | 100.0     |
| 0°-90°    | 6785.0 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 6785.0 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°    | Flux |
|-----|-------|------|
| 0°  | 10842 |      |
| 5°  | 10628 | 973  |
| 15° | 7553  | 2115 |
| 25° | 5034  | 2271 |
| 35° | 1928  | 1227 |
| 45° | 177   | 191  |
| 55° | 0     | 5    |
| 65° | 0     | 1    |
| 75° | 0     | 0    |
| 85° | 0     | 0    |
| 90° | 0     |      |



TEST NUMBER: P250302

CATALOG NUMBER: LSR8B80D010 EC8B80835 8LBN0GPH

**CANDELA DISTRIBUTION (FULL):**

| 0°    |         |
|-------|---------|
| 0°    | 10841.8 |
| 1°    | 10862.3 |
| 2°    | 10852.1 |
| 3°    | 10815.0 |
| 4°    | 10743.6 |
| 5°    | 10627.9 |
| 6°    | 10468.7 |
| 7°    | 10254.5 |
| 8°    | 9986.4  |
| 9°    | 9677.9  |
| 10°   | 9334.7  |
| 11°   | 8974.8  |
| 12°   | 8601.5  |
| 13°   | 8228.4  |
| 14°   | 7881.8  |
| 15°   | 7552.7  |
| 16°   | 7250.5  |
| 17°   | 6958.6  |
| 18°   | 6687.0  |
| 19°   | 6432.7  |
| 20°   | 6188.1  |
| 21°   | 5950.4  |
| 22°   | 5726.2  |
| 23°   | 5502.6  |
| 24°   | 5268.3  |
| 25°   | 5033.9  |
| 26°   | 4796.2  |
| 27°   | 4524.8  |
| 28°   | 4226.0  |
| 29°   | 3920.9  |
| 30°   | 3601.6  |
| 31°   | 3258.8  |
| 32°   | 2915.7  |
| 33°   | 2576.3  |
| 34°   | 2233.6  |
| 35°   | 1927.9  |
| 37.5° | 1232.2  |
| 40°   | 712.9   |
| 42.5° | 380.3   |
| 45°   | 176.7   |
| 47.5° | 95.2    |
| 50°   | 30.8    |
| 52.5° | 3.5     |
| 55°   | 0.0     |
| 57.5° | 3.5     |



TEST NUMBER: P250302

CATALOG NUMBER: LSR8B80D010 EC8B80835 8LBN0GPH

**CANDELA DISTRIBUTION (continued):**

|       | 0°  |
|-------|-----|
| 60°   | 3.5 |
| 62.5° | 0.0 |
| 65°   | 0.0 |
| 67.5° | 3.5 |
| 70°   | 0.0 |
| 72.5° | 0.0 |
| 75°   | 0.0 |
| 77.5° | 0.0 |
| 80°   | 0.0 |
| 82.5° | 0.0 |
| 85°   | 0.0 |
| 87.5° | 0.0 |
| 90°   | 0.0 |

(END OF REPORT)