

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P249814

Luminaire Tested: **LD8B100D010 ER8B100850 8LBN0H**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P249814
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P13959)
Test Lab: INNOVATION CENTER-P1
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B100D010 ER8B100850 8LBN0H
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED
DOWNLIGHT
80 CRI 5000 CCT WITH SEMI-SPECULAR CLEAR TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 9922.0 lumens
Efficiency: N/A
Efficacy: 93.3 lumens/watt
Spacing Criteria (0/90/45): 0.77 / 0.77 / 0.81
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 106.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P249814

CATALOG NUMBER: LD8B100D010 ER8B100850 8LBN0H

Luminous Intensity Polar Plot





TEST NUMBER: P249814

CATALOG NUMBER: LD8B100D010 ER8B100850 8LBNOH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | 0 |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |
| 1 | 114 | 111 | 109 | 106 | 111 | 109 | 107 | 105 | 105 | 103 | 101 | 101 | 100 | 98 | 98 | 97 | 96 | 94 |
| 2 | 108 | 103 | 100 | 96 | 106 | 102 | 98 | 95 | 99 | 96 | 93 | 96 | 93 | 91 | 93 | 91 | 89 | 88 |
| 3 | 103 | 97 | 92 | 88 | 101 | 95 | 91 | 87 | 93 | 89 | 86 | 90 | 87 | 85 | 88 | 85 | 83 | 82 |
| 4 | 98 | 91 | 85 | 81 | 96 | 89 | 84 | 81 | 87 | 83 | 80 | 85 | 82 | 79 | 83 | 80 | 78 | 76 |
| 5 | 93 | 85 | 79 | 75 | 92 | 84 | 79 | 75 | 82 | 78 | 74 | 81 | 77 | 74 | 79 | 76 | 73 | 71 |
| 6 | 89 | 80 | 74 | 70 | 87 | 79 | 74 | 70 | 78 | 73 | 69 | 76 | 72 | 69 | 75 | 71 | 68 | 67 |
| 7 | 84 | 75 | 70 | 66 | 83 | 75 | 69 | 65 | 74 | 69 | 65 | 72 | 68 | 65 | 71 | 67 | 64 | 63 |
| 8 | 81 | 71 | 65 | 62 | 79 | 71 | 65 | 61 | 70 | 65 | 61 | 69 | 64 | 61 | 68 | 64 | 61 | 59 |
| 9 | 77 | 68 | 62 | 58 | 76 | 67 | 62 | 58 | 66 | 61 | 58 | 65 | 61 | 57 | 64 | 60 | 57 | 56 |
| 10 | 73 | 64 | 58 | 55 | 72 | 64 | 58 | 55 | 63 | 58 | 54 | 62 | 57 | 54 | 61 | 57 | 54 | 53 |

AVERAGE LUMINANCE (cd/sqm):

| | |
|-----|--------|
| | 0° |
| 0° | 419642 |
| 5° | 414488 |
| 10° | 382799 |
| 15° | 333792 |
| 20° | 285926 |
| 25° | 239336 |
| 30° | 182082 |
| 35° | 112872 |
| 40° | 55687 |
| 45° | 26501 |
| 50° | 12885 |
| 55° | 6317 |
| 60° | 3935 |
| 65° | 2692 |
| 70° | 1515 |
| 75° | 1203 |
| 80° | 1190 |
| 85° | 1203 |



TEST NUMBER: P249814

CATALOG NUMBER: LD8B100D010 ER8B100850 8LBNOH

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 1241.0 | 12.5 |
| 10°-20° | 2913.4 | 29.4 |
| 20°-30° | 3184.2 | 32.1 |
| 30°-40° | 1894.9 | 19.1 |
| 40°-50° | 519.7 | 5.2 |
| 50°-60° | 117.7 | 1.2 |
| 60°-70° | 36.4 | 0.4 |
| 70°-80° | 11.1 | 0.1 |
| 80°-90° | 3.7 | 0.0 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 7338.5 | 74.0 |
| 0°-40° | 9233.4 | 93.1 |
| 0°-60° | 9870.9 | 99.5 |
| 0°-90° | 9922.0 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 9922.0 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|-------|------|
| 0° | 13609 | |
| 5° | 13390 | ### |
| 15° | 10456 | 2913 |
| 25° | 7034 | 3184 |
| 35° | 2998 | 1895 |
| 45° | 608 | 520 |
| 55° | 118 | 118 |
| 65° | 37 | 36 |
| 75° | 10 | 11 |
| 85° | 3 | 4 |
| 90° | 0 | |



TEST NUMBER: P249814

CATALOG NUMBER: LD8B100D010 ER8B100850 8LBNOH

CANDELA DISTRIBUTION (FULL):

| 0° | |
|-------|---------|
| 0° | 13608.7 |
| 1° | 13635.5 |
| 2° | 13618.7 |
| 3° | 13585.2 |
| 4° | 13507.9 |
| 5° | 13390.4 |
| 6° | 13239.3 |
| 7° | 13037.9 |
| 8° | 12802.8 |
| 9° | 12530.9 |
| 10° | 12225.3 |
| 11° | 11899.6 |
| 12° | 11550.4 |
| 13° | 11191.1 |
| 14° | 10818.4 |
| 15° | 10455.8 |
| 16° | 10099.9 |
| 17° | 9750.7 |
| 18° | 9401.5 |
| 19° | 9052.3 |
| 20° | 8713.2 |
| 22.5° | 7860.3 |
| 25° | 7034.3 |
| 27.5° | 6124.4 |
| 30° | 5113.7 |
| 32.5° | 4029.2 |
| 35° | 2998.4 |
| 37.5° | 2085.1 |
| 40° | 1383.4 |
| 42.5° | 906.6 |
| 45° | 607.7 |
| 47.5° | 402.9 |
| 50° | 268.6 |
| 52.5° | 164.5 |
| 55° | 117.5 |
| 57.5° | 83.9 |
| 60° | 63.8 |
| 62.5° | 47.0 |
| 65° | 36.9 |
| 67.5° | 23.5 |
| 70° | 16.8 |
| 72.5° | 13.4 |
| 75° | 10.1 |
| 77.5° | 6.7 |
| 80° | 6.7 |



TEST NUMBER: P249814

CATALOG NUMBER: LD8B100D010 ER8B100850 8LBNOH

CANDELA DISTRIBUTION (continued):

| | 0° |
|-------|-----|
| 82.5° | 3.4 |
| 85° | 3.4 |
| 87.5° | 3.4 |
| 90° | 0.0 |

(END OF REPORT)