

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P250612

Luminaire Tested: **LD8B100D010 ER8B1009727 8LBM0B**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P250612
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P13928)
Test Lab: INNOVATION CENTER-P1
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B100D010 ER8B1009727 8LBM0B
Description: PORTFOLIO 8 INCH MEDIUM DISTRIBUTION 55 DEG CUTOFF RECESSED
DOWNLIGHT
97 CRI 2700 CCT WITH SPECULAR BLACK TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4828.0 lumens
Efficiency: N/A
Efficacy: 45.4 lumens/watt
Spacing Criteria (0/90/45): 0.79 / 0.79 / 0.87
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 106.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P250612

CATALOG NUMBER: LD8B100D010 ER8B1009727 8LBM0B

Luminous Intensity Polar Plot





TEST NUMBER: P250612

CATALOG NUMBER: LD8B100D010 ER8B1009727 8LBM0B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	111	108	106	111	109	107	105	105	103	101		101	100	98		98	97	96	94
2	108	103	99	96	106	102	98	95	98	95	93		95	93	91		93	91	89	87
3	103	96	92	88	101	95	91	87	92	89	86		90	87	84		88	85	83	81
4	98	90	85	81	96	89	84	80	87	83	79		85	81	78		83	80	77	76
5	93	85	79	75	91	84	78	74	82	77	74		80	76	73		79	75	72	71
6	88	79	74	69	87	79	73	69	77	72	69		76	71	68		74	71	68	66
7	84	75	69	65	83	74	68	64	73	68	64		72	67	64		70	66	63	62
8	80	70	64	60	79	70	64	60	69	64	60		68	63	60		67	63	60	58
9	76	66	61	57	75	66	60	57	65	60	56		64	60	56		63	59	56	55
10	72	63	57	53	71	62	57	53	62	57	53		61	56	53		60	56	53	51

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P250612

CATALOG NUMBER: LD8B100D010 ER8B1009727 8LBM0B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	550.2	11.4
10°-20°	1277.8	26.5
20°-30°	1621.1	33.6
30°-40°	1110.6	23.0
40°-50°	253.1	5.2
50°-60°	12.6	0.3
60°-70°	0.6	0.0
70°-80°	0.9	0.0
80°-90°	0.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3449.2	71.4
0°-40°	4559.8	94.4
0°-60°	4825.5	99.9
0°-90°	4828.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4828.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6264	
5°	6050	550
15°	4536	1278
25°	3591	1621
35°	1794	1111
45°	273	253
55°	5	13
65°	2	1
75°	0	1
85°	0	1
90°	0	



TEST NUMBER: P250612

CATALOG NUMBER: LD8B100D010 ER8B1009727 8LBM0B

CANDELA DISTRIBUTION (FULL):

0°	
0°	6264.5
1°	6297.1
2°	6285.4
3°	6238.8
4°	6159.5
5°	6049.8
6°	5916.8
7°	5762.9
8°	5592.5
9°	5410.5
10°	5237.9
11°	5079.2
12°	4908.9
13°	4785.3
14°	4654.6
15°	4535.6
16°	4428.3
17°	4323.3
18°	4225.3
19°	4129.6
20°	4043.3
21°	3954.7
22°	3863.7
23°	3784.4
24°	3695.7
25°	3590.7
26°	3474.0
27°	3338.7
28°	3194.1
29°	3033.1
30°	2855.8
31°	2655.1
32°	2447.5
33°	2230.5
34°	2008.8
35°	1794.2
37.5°	1266.9
40°	816.6
42.5°	480.6
45°	273.0
47.5°	147.0
50°	74.7
52.5°	14.0
55°	4.7
57.5°	2.3



TEST NUMBER: P250612

CATALOG NUMBER: LD8B100D010 ER8B1009727 8LBM0B

CANDELA DISTRIBUTION (continued):

	0°
60°	0.0
62.5°	0.0
65°	2.3
67.5°	0.0
70°	0.0
72.5°	2.3
75°	0.0
77.5°	0.0
80°	2.3
82.5°	0.0
85°	0.0
87.5°	2.3
90°	0.0

(END OF REPORT)