

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P250451

Luminaire Tested: **LD8B100D010 ER8B1009730 8LBN0B**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P250451
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P13948)
Test Lab: INNOVATION CENTER-P1
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B100D010 ER8B1009730 8LBN0B
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED
DOWNLIGHT
97 CRI 3000 CCT WITH SPECULAR BLACK TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4731.0 lumens
Efficiency: N/A
Efficacy: 44.5 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.77
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 106.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P250451

CATALOG NUMBER: LD8B100D010 ER8B1009730 8LBN0B

Luminous Intensity Polar Plot





TEST NUMBER: P250451

CATALOG NUMBER: LD8B100D010 ER8B1009730 8LBN0B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	107	112	109	107	105	105	104	102	101	100	99	98	97	96	94
2	109	104	101	97	107	103	99	96	99	97	94	96	94	92	94	92	90	89
3	104	98	93	90	102	97	92	89	94	90	88	92	89	86	89	87	85	83
4	99	92	87	83	97	91	86	83	89	85	82	87	84	81	85	82	80	78
5	95	87	82	78	93	86	81	77	84	80	77	83	79	76	81	78	75	74
6	90	82	77	73	89	81	76	72	80	75	72	79	75	71	77	74	71	70
7	86	78	72	68	85	77	72	68	76	71	68	75	71	67	74	70	67	66
8	83	74	68	64	81	73	68	64	72	67	64	71	67	64	70	66	63	62
9	79	70	65	61	78	70	64	61	69	64	61	68	63	60	67	63	60	59
10	76	67	61	58	75	66	61	58	65	61	57	65	60	57	64	60	57	56

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P250451

CATALOG NUMBER: LD8B100D010 ER8B1009730 8LBN0B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	678.6	14.3
10°-20°	1475.0	31.2
20°-30°	1583.5	33.5
30°-40°	855.8	18.1
40°-50°	133.5	2.8
50°-60°	3.7	0.1
60°-70°	0.9	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3737.1	79.0
0°-40°	4592.9	97.1
0°-60°	4730.1	100.0
0°-90°	4731.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4731.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	7560	
5°	7411	679
15°	5266	1475
25°	3510	1583
35°	1344	856
45°	123	134
55°	0	4
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P250451

CATALOG NUMBER: LD8B100D010 ER8B1009730 8LBN0B

CANDELA DISTRIBUTION (FULL):

0°	
0°	7559.7
1°	7574.0
2°	7566.9
3°	7541.0
4°	7491.2
5°	7410.6
6°	7299.6
7°	7150.2
8°	6963.3
9°	6748.1
10°	6508.9
11°	6257.9
12°	5997.6
13°	5737.5
14°	5495.8
15°	5266.3
16°	5055.6
17°	4852.0
18°	4662.7
19°	4485.4
20°	4314.8
21°	4149.1
22°	3992.8
23°	3836.8
24°	3673.5
25°	3510.0
26°	3344.3
27°	3155.1
28°	2946.7
29°	2733.9
30°	2511.3
31°	2272.3
32°	2033.0
33°	1796.4
34°	1557.4
35°	1344.3
37.5°	859.2
40°	497.1
42.5°	265.2
45°	123.2
47.5°	66.4
50°	21.5
52.5°	2.4
55°	0.0
57.5°	2.4



TEST NUMBER: P250451

CATALOG NUMBER: LD8B100D010 ER8B1009730 8LBN0B

CANDELA DISTRIBUTION (continued):

	0°
60°	2.4
62.5°	0.0
65°	0.0
67.5°	2.4
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)