

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P245743

Luminaire Tested: **LD8B15D010 ER8B15827 8LBS0GPH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P245743
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-16)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B15D010 ER8B15827 8LBS0GPH
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT
80 CRI 2700 CCT WITH GRAPHITE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1431.0 lumens
Efficiency: N/A
Efficacy: 99.4 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.25
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 14.4
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P245743

CATALOG NUMBER: LD8B15D010 ER8B15827 8LBS0GPH

Luminous Intensity Polar Plot





TEST NUMBER: P245743

CATALOG NUMBER: LD8B15D010 ER8B15827 8LBS0GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	109	106	103	110	107	104	102	103	100	98		99	97	95		95	94	93	91
2	105	99	94	90	103	97	93	89	94	90	87		91	88	85		88	85	83	81
3	98	90	84	79	96	88	83	78	86	81	77		83	79	76		81	77	74	73
4	91	82	75	70	89	81	74	69	78	73	69		76	72	68		74	70	67	65
5	85	75	68	62	83	74	67	62	72	66	61		70	65	61		68	64	60	58
6	79	69	61	56	78	68	61	56	66	60	55		64	59	55		63	58	54	53
7	74	63	56	50	73	62	55	50	61	55	50		59	54	50		58	53	49	48
8	70	58	51	46	68	57	50	46	56	50	45		55	49	45		54	49	45	43
9	65	54	47	42	64	53	46	42	52	46	41		51	45	41		50	45	41	40
10	62	50	43	38	60	49	43	38	48	42	38		48	42	38		47	42	38	36

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	25329
5°	25252
10°	25003
15°	24748
20°	24487
25°	24086
30°	23429
35°	22361
40°	20791
45°	17553
50°	11916
55°	6226
60°	2794
65°	1364
70°	550
75°	334
80°	249
85°	177



TEST NUMBER: P245743

CATALOG NUMBER: LD8B15D010 ER8B15827 8LBS0GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	77.3	5.4
10°-20°	218.7	15.3
20°-30°	325.5	22.7
30°-40°	370.0	25.9
40°-50°	302.5	21.1
50°-60°	112.8	7.9
60°-70°	20.6	1.4
70°-80°	3.2	0.2
80°-90°	0.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	621.5	43.4
0°-40°	991.4	69.3
0°-60°	1406.7	98.3
0°-90°	1431.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1431.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	821	
5°	816	77
15°	775	219
25°	708	325
35°	594	370
45°	402	303
55°	116	113
65°	19	21
75°	3	3
85°	0	0
90°	0	



TEST NUMBER: P245743

CATALOG NUMBER: LD8B15D010 ER8B15827 8LBS0GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	821.4
2.5°	820.0
5°	815.8
7.5°	808.3
10°	798.5
12.5°	787.3
15°	775.2
17.5°	761.2
20°	746.2
22.5°	728.5
25°	707.9
27.5°	684.6
30°	658.0
32.5°	627.6
35°	594.0
37.5°	558.0
40°	516.5
42.5°	465.1
45°	402.5
47.5°	327.3
50°	248.4
52.5°	175.1
55°	115.8
57.5°	72.8
60°	45.3
62.5°	29.0
65°	18.7
67.5°	10.7
70°	6.1
72.5°	3.7
75°	2.8
77.5°	1.9
80°	1.4
82.5°	0.5
85°	0.5
87.5°	0.0
90°	0.0

(END OF REPORT)