

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P249652

Luminaire Tested: **LD8B150D010 ER8B150927 8LBS0GPH**

Issue Date: 03/03/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P249652  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-95)  
Test Lab: INNOVATION CENTER(G1)  
Issue Date: 03/03/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LD8B150D010 ER8B150927 8LBS0GPH  
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED  
DOWNLIGHT  
97 CRI 2700 CCT WITH GRAPHITE TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 12654.0 lumens  
Efficiency: N/A  
Efficacy: 79.8 lumens/watt  
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.22  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 158.5  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P249652

CATALOG NUMBER: LD8B150D010 ER8B150927 8LBS0GPH

### Luminous Intensity Polar Plot





TEST NUMBER: P249652

CATALOG NUMBER: LD8B150D010 ER8B150927 8LBS0GPH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	112	109	106	103	110	107	104	101	102	100	98	99	97	95	95	94	93	91
2	105	99	94	90	102	97	92	89	94	90	87	91	87	85	88	85	83	81
3	98	90	84	79	96	88	83	78	85	81	77	83	79	75	81	77	74	72
4	91	82	75	69	89	80	74	69	78	73	68	76	71	67	74	70	66	65
5	85	75	67	62	83	73	67	62	72	66	61	70	64	60	68	63	60	58
6	79	68	61	56	78	67	60	55	66	59	55	64	59	54	63	58	54	52
7	74	63	55	50	73	62	55	50	61	54	50	59	54	49	58	53	49	47
8	69	58	51	45	68	57	50	45	56	50	45	55	49	45	54	49	45	43
9	65	54	46	42	64	53	46	41	52	46	41	51	45	41	50	45	41	39
10	61	50	43	38	60	49	43	38	48	42	38	47	42	38	47	41	38	36

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P249652

CATALOG NUMBER: LD8B150D010 ER8B150927 8LBS0GPH

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	686.4	5.4
10°-20°	1951.6	15.4
20°-30°	2873.9	22.7
30°-40°	3199.8	25.3
40°-50°	2527.2	20.0
50°-60°	1133.0	9.0
60°-70°	250.1	2.0
70°-80°	28.2	0.2
80°-90°	3.8	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	5511.9	43.6
0°-40°	8711.7	68.8
0°-60°	12371.9	97.8
0°-90°	12654.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	12654.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	7266	
5°	7226	686
15°	6926	1952
25°	6257	2874
35°	5144	3200
45°	3302	2527
55°	1223	1133
65°	219	250
75°	23	28
85°	2	4
90°	0	



TEST NUMBER: P249652

CATALOG NUMBER: LD8B150D010 ER8B150927 8LBS0GPH

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	7266.4
2.5°	7255.5
5°	7226.4
7.5°	7181.8
10°	7118.3
12.5°	7032.9
15°	6926.4
17.5°	6796.5
20°	6640.5
22.5°	6461.2
25°	6256.8
27.5°	6021.0
30°	5759.4
32.5°	5459.4
35°	5143.7
37.5°	4804.5
40°	4384.8
42.5°	3865.4
45°	3302.2
47.5°	2728.9
50°	2172.0
52.5°	1662.9
55°	1223.4
57.5°	854.6
60°	572.6
62.5°	362.7
65°	219.3
67.5°	122.2
70°	60.3
72.5°	32.8
75°	22.7
77.5°	16.4
80°	10.2
82.5°	5.5
85°	2.4
87.5°	0.8
90°	0.0

(END OF REPORT)