

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P250426

Luminaire Tested: **LD8B175D010 ER8B175935 8LBN0B**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P250426
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P13948)
Test Lab: INNOVATION CENTER-P1
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B175D010 ER8B175935 8LBN0B
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED
DOWNLIGHT
90 CRI 3500 CCT WITH SPECULAR BLACK TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 8900.0 lumens
Efficiency: N/A
Efficacy: 50.2 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.77
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 177.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P250426

CATALOG NUMBER: LD8B175D010 ER8B175935 8LBN0B

Luminous Intensity Polar Plot





TEST NUMBER: P250426

CATALOG NUMBER: LD8B175D010 ER8B175935 8LBN0B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	107	112	109	107	105	105	104	102	101	100	99	98	97	96	94
2	109	104	101	97	107	103	99	96	99	97	94	96	94	92	94	92	90	89
3	104	98	93	90	102	97	92	89	94	90	88	92	89	86	89	87	85	83
4	99	92	87	83	97	91	86	83	89	85	82	87	84	81	85	82	80	78
5	95	87	82	78	93	86	81	77	84	80	77	83	79	76	81	78	75	74
6	90	82	77	73	89	81	76	72	80	75	72	79	75	71	77	74	71	70
7	86	78	72	68	85	77	72	68	76	71	68	75	71	67	74	70	67	66
8	83	74	68	64	81	73	68	64	72	67	64	71	67	64	70	66	63	62
9	79	70	65	61	78	70	64	61	69	64	61	68	63	60	67	63	60	59
10	76	67	61	58	75	66	61	58	65	61	57	65	60	57	64	60	57	56

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	438532
5°	431525
10°	383400
15°	316272
20°	266365
25°	224665
30°	168217
35°	95198
40°	37641
45°	10104
50°	1938
55°	0
60°	278
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P250426

CATALOG NUMBER: LD8B175D010 ER8B175935 8LBN0B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1276.6	14.3
10°-20°	2774.7	31.2
20°-30°	2978.9	33.5
30°-40°	1610.0	18.1
40°-50°	251.2	2.8
50°-60°	6.9	0.1
60°-70°	1.7	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	7030.2	79.0
0°-40°	8640.2	97.1
0°-60°	8898.3	100.0
0°-90°	8900.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8900.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14221	
5°	13941	###
15°	9907	2775
25°	6603	2979
35°	2529	1610
45°	232	251
55°	0	7
65°	0	2
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P250426

CATALOG NUMBER: LD8B175D010 ER8B175935 8LBN0B

CANDELA DISTRIBUTION (FULL):

0°	
0°	14221.3
1°	14248.3
2°	14234.9
3°	14186.2
4°	14092.5
5°	13940.8
6°	13732.0
7°	13451.1
8°	13099.4
9°	12694.6
10°	12244.5
11°	11772.5
12°	11282.7
13°	10793.4
14°	10338.7
15°	9907.0
16°	9510.7
17°	9127.7
18°	8771.5
19°	8437.9
20°	8117.1
21°	7805.3
22°	7511.2
23°	7217.8
24°	6910.6
25°	6603.1
26°	6291.3
27°	5935.3
28°	5543.3
29°	5143.1
30°	4724.3
31°	4274.6
32°	3824.5
33°	3379.4
34°	2929.8
35°	2528.9
37.5°	1616.3
40°	935.1
42.5°	498.8
45°	231.7
47.5°	124.9
50°	40.4
52.5°	4.5
55°	0.0
57.5°	4.5



TEST NUMBER: P250426

CATALOG NUMBER: LD8B175D010 ER8B175935 8LBN0B

CANDELA DISTRIBUTION (continued):

	0°
60°	4.5
62.5°	0.0
65°	0.0
67.5°	4.5
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)