

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P250433

Luminaire Tested: **LD8B175D010 ER8B175940 8LBN0B**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P250433
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P13948)
Test Lab: INNOVATION CENTER-P1
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B175D010 ER8B175940 8LBN0B
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED
DOWNLIGHT
90 CRI 4000 CCT WITH SPECULAR BLACK TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 9295.0 lumens
Efficiency: N/A
Efficacy: 52.5 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.77
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 177.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P250433

CATALOG NUMBER: LD8B175D010 ER8B175940 8LBN0B

Luminous Intensity Polar Plot





TEST NUMBER: P250433

CATALOG NUMBER: LD8B175D010 ER8B175940 8LBN0B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	107	112	109	107	105	105	104	102	101	100	99	98	97	96	94
2	109	104	101	97	107	103	99	96	99	97	94	96	94	92	94	92	90	89
3	104	98	93	90	102	97	92	89	94	90	88	92	89	86	89	87	85	83
4	99	92	87	83	97	91	86	83	89	85	82	87	84	81	85	82	80	78
5	95	87	82	78	93	86	81	77	84	80	77	83	79	76	81	78	75	74
6	90	82	77	73	89	81	76	72	80	75	72	79	75	71	77	74	71	70
7	86	78	72	68	85	77	72	68	76	71	68	75	71	67	74	70	67	66
8	83	74	68	64	81	73	68	64	72	67	64	71	67	64	70	66	63	62
9	79	70	65	61	78	70	64	61	69	64	61	68	63	60	67	63	60	59
10	76	67	61	58	75	66	61	58	65	61	57	65	60	57	64	60	57	56

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	457996
5°	450679
10°	400418
15°	330309
20°	278185
25°	234634
30°	175680
35°	99422
40°	39312
45°	10553
50°	2024
55°	0
60°	290
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P250433

CATALOG NUMBER: LD8B175D010 ER8B175940 8LBN0B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1333.3	14.3
10°-20°	2897.9	31.2
20°-30°	3111.1	33.5
30°-40°	1681.5	18.1
40°-50°	262.3	2.8
50°-60°	7.2	0.1
60°-70°	1.8	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	7342.2	79.0
0°-40°	9023.7	97.1
0°-60°	9293.2	100.0
0°-90°	9295.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	9295.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14852	
5°	14560	###
15°	10347	2898
25°	6896	3111
35°	2641	1681
45°	242	262
55°	0	7
65°	0	2
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P250433

CATALOG NUMBER: LD8B175D010 ER8B175940 8LBN0B

CANDELA DISTRIBUTION (FULL):

	0°
0°	14852.5
1°	14880.7
2°	14866.7
3°	14815.8
4°	14718.0
5°	14559.6
6°	14341.5
7°	14048.0
8°	13680.8
9°	13258.1
10°	12788.0
11°	12294.9
12°	11783.4
13°	11272.4
14°	10797.6
15°	10346.7
16°	9932.8
17°	9532.8
18°	9160.8
19°	8812.4
20°	8477.3
21°	8151.7
22°	7844.6
23°	7538.1
24°	7217.3
25°	6896.1
26°	6570.5
27°	6198.7
28°	5789.3
29°	5371.3
30°	4933.9
31°	4464.3
32°	3994.3
33°	3529.4
34°	3059.8
35°	2641.1
37.5°	1688.0
40°	976.6
42.5°	521.0
45°	242.0
47.5°	130.5
50°	42.2
52.5°	4.7
55°	0.0
57.5°	4.7



TEST NUMBER: P250433

CATALOG NUMBER: LD8B175D010 ER8B175940 8LBN0B

CANDELA DISTRIBUTION (continued):

	0°
60°	4.7
62.5°	0.0
65°	0.0
67.5°	4.7
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)