

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P250118

Luminaire Tested: **LD8B175D010 ER8B1759730 8LBN0WH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P250118
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P13946)
Test Lab: INNOVATION CENTER-P1
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B175D010 ER8B1759730 8LBN0WH
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED
DOWNLIGHT
97 CRI 3000 CCT WITH WHEAT TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 12160.0 lumens
Efficiency: N/A
Efficacy: 68.6 lumens/watt
Spacing Criteria (0/90/45): 0.58 / 0.58 / 0.66
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 177.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P250118

CATALOG NUMBER: LD8B175D010 ER8B1759730 8LBN0WH

Luminous Intensity Polar Plot





TEST NUMBER: P250118

CATALOG NUMBER: LD8B175D010 ER8B1759730 8LBN0WH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	112	109	107	112	109	107	106	105	104	102		102	100	99		98	97	96	95
2	109	105	101	98	107	103	100	97	100	97	95		97	95	93		94	93	91	89
3	105	99	94	91	103	97	93	90	95	91	89		92	90	87		90	88	86	85
4	100	93	88	85	98	92	88	84	90	86	83		88	85	82		86	84	81	80
5	96	88	83	79	94	87	83	79	86	82	78		84	81	78		83	80	77	76
6	92	84	79	75	90	83	78	74	82	77	74		80	76	74		79	76	73	72
7	88	80	74	71	87	79	74	70	78	73	70		77	73	70		76	72	69	68
8	84	76	71	67	83	75	70	67	74	70	67		73	69	66		72	69	66	65
9	81	72	67	64	80	72	67	64	71	66	63		70	66	63		69	66	63	62
10	78	69	64	61	77	69	64	61	68	63	60		67	63	60		67	63	60	59

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P250118

CATALOG NUMBER: LD8B175D010 ER8B1759730 8LBN0WH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	2134.9	17.6
10°-20°	4136.9	34.0
20°-30°	3724.5	30.6
30°-40°	1842.7	15.2
40°-50°	280.3	2.3
50°-60°	11.5	0.1
60°-70°	14.8	0.1
70°-80°	5.6	0.0
80°-90°	8.7	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	9996.3	82.2
0°-40°	11839.1	97.4
0°-60°	12130.9	99.8
0°-90°	12160.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	12160.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	24445	
5°	23549	###
15°	14821	4137
25°	8236	3725
35°	2983	1843
45°	310	280
55°	4	12
65°	8	15
75°	8	6
85°	13	9
90°	0	



TEST NUMBER: P250118

CATALOG NUMBER: LD8B175D010 ER8B1759730 8LBN0WH

CANDELA DISTRIBUTION (FULL):

	0°
0°	24444.6
1°	24393.7
2°	24406.3
3°	24283.2
4°	24058.4
5°	23549.3
6°	23158.9
7°	22539.4
8°	21707.8
9°	20842.1
10°	19798.2
11°	18864.8
12°	17863.5
13°	16756.0
14°	15801.3
15°	14821.1
16°	13985.2
17°	13247.0
18°	12338.9
19°	11672.7
20°	11019.4
21°	10340.4
22°	9844.0
23°	9266.9
24°	8736.5
25°	8235.8
26°	7646.0
27°	7115.7
28°	6640.4
29°	6118.5
30°	5367.5
31°	4943.3
32°	4408.6
33°	3823.0
34°	3377.5
35°	2982.8
37.5°	1888.1
40°	852.9
42.5°	581.3
45°	309.7
47.5°	173.9
50°	4.3
52.5°	17.0
55°	4.3
57.5°	25.5



TEST NUMBER: P250118

CATALOG NUMBER: LD8B175D010 ER8B1759730 8LBN0WH

CANDELA DISTRIBUTION (continued):

	0°
60°	4.3
62.5°	21.3
65°	8.5
67.5°	21.3
70°	12.8
72.5°	4.3
75°	8.5
77.5°	0.0
80°	4.3
82.5°	17.0
85°	12.8
87.5°	0.0
90°	0.0

(END OF REPORT)