

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P244514

Luminaire Tested: **LD8B20D010 ER8B209730 8LBS0H**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P244514
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-13)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B20D010 ER8B209730 8LBS0H
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT
97 CRI 3000 CCT WITH SEMI-SPECULAR CLEAR TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1751.0 lumens
Efficiency: N/A
Efficacy: 82.2 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.2 / 1.23
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 21.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P244514

CATALOG NUMBER: LD8B20D010 ER8B209730 8LBS0H

Luminous Intensity Polar Plot





TEST NUMBER: P244514

CATALOG NUMBER: LD8B20D010 ER8B209730 8LBS0H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	109	106	103	110	107	104	102	103	100	98		99	97	95		95	94	93	91
2	105	99	94	90	103	97	93	89	94	90	87		91	88	85		88	85	83	81
3	98	90	84	79	96	89	83	78	86	81	77		83	79	76		81	78	75	73
4	91	82	75	70	89	81	75	70	79	73	69		76	72	68		74	70	67	65
5	85	75	68	63	83	74	67	62	72	66	62		70	65	61		69	64	60	59
6	80	69	61	56	78	68	61	56	66	60	56		65	59	55		63	58	55	53
7	75	63	56	51	73	63	56	51	61	55	50		60	54	50		59	54	50	48
8	70	58	51	46	68	58	51	46	57	50	46		55	50	46		54	49	45	44
9	66	54	47	42	64	53	47	42	52	46	42		51	46	42		51	45	42	40
10	62	50	43	39	61	50	43	39	49	43	38		48	42	38		47	42	38	37

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P244514

CATALOG NUMBER: LD8B20D010 ER8B209730 8LBS0H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	95.7	5.5
10°-20°	272.1	15.5
20°-30°	407.0	23.2
30°-40°	455.3	26.0
40°-50°	357.2	20.4
50°-60°	130.3	7.4
60°-70°	26.6	1.5
70°-80°	5.7	0.3
80°-90°	1.2	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	774.8	44.2
0°-40°	1230.1	70.2
0°-60°	1717.6	98.1
0°-90°	1751.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1751.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1016	
5°	1009	96
15°	964	272
25°	887	407
35°	733	455
45°	473	357
55°	133	130
65°	24	27
75°	5	6
85°	1	1
90°	0	



TEST NUMBER: P244514

CATALOG NUMBER: LD8B20D010 ER8B209730 8LBS0H

CANDELA DISTRIBUTION (FULL):

	0°
0°	1016.2
2.5°	1014.6
5°	1008.9
7.5°	1000.7
10°	989.8
12.5°	977.4
15°	964.0
17.5°	949.0
20°	931.5
22.5°	910.8
25°	886.6
27.5°	856.6
30°	821.0
32.5°	779.2
35°	732.7
37.5°	680.5
40°	622.7
42.5°	554.0
45°	473.0
47.5°	381.6
50°	286.6
52.5°	200.9
55°	133.2
57.5°	85.2
60°	54.7
62.5°	36.1
65°	24.3
67.5°	15.5
70°	9.8
72.5°	6.7
75°	5.2
77.5°	3.6
80°	2.6
82.5°	1.5
85°	1.0
87.5°	0.5
90°	0.0

(END OF REPORT)