

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P248014

Luminaire Tested: **LD8B200D010 ER8B2009727 8LBW0WMH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P248014
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-71)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B200D010 ER8B2009727 8LBW0WMH
Description: PORTFOLIO 8 INCH WIDE DISTRIBUTION 60 DEGREE CUTOFF RECESSED
DOWNLIGHT
97 CRI 2700 CCT WITH WARM HAZE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 14685.0 lumens
Efficiency: N/A
Efficacy: 65.8 lumens/watt
Spacing Criteria (0/90/45): 1.12 / 1.12 / 1.06
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 223.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P248014

CATALOG NUMBER: LD8B200D010 ER8B2009727 8LBW0WMH

Luminous Intensity Polar Plot





TEST NUMBER: P248014

CATALOG NUMBER: LD8B200D010 ER8B2009727 8LBW0WMH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	112	109	106	104	110	107	104	102	103	101	99	99	97	96	96	94	93	91
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	86	84	82
3	99	91	85	81	97	90	84	80	87	82	79	85	81	77	82	79	76	74
4	93	84	77	72	91	82	76	72	80	75	71	78	74	70	76	72	69	67
5	87	77	70	65	85	76	70	65	74	68	64	72	67	64	71	66	63	61
6	82	71	64	59	80	70	64	59	69	63	58	67	62	58	66	61	58	56
7	77	66	59	54	75	65	58	54	64	58	53	62	57	53	61	56	53	51
8	72	61	54	49	71	61	54	49	59	53	49	58	53	49	57	52	49	47
9	68	57	50	46	67	56	50	46	55	49	45	54	49	45	54	49	45	43
10	64	53	47	42	63	53	46	42	52	46	42	51	46	42	50	45	42	40

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P248014

CATALOG NUMBER: LD8B200D010 ER8B2009727 8LBW0WMH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	971.0	6.6
10°-20°	2734.6	18.6
20°-30°	3993.4	27.2
30°-40°	3591.5	24.5
40°-50°	1964.2	13.4
50°-60°	973.8	6.6
60°-70°	384.6	2.6
70°-80°	62.0	0.4
80°-90°	10.1	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	7699.0	52.4
0°-40°	11290.5	76.9
0°-60°	14228.4	96.9
0°-90°	14685.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	14685.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	10362	
5°	10253	971
15°	9689	2735
25°	8813	3993
35°	5796	3591
45°	2446	1964
55°	1056	974
65°	385	385
75°	47	62
85°	13	10
90°	0	



TEST NUMBER: P248014

CATALOG NUMBER: LD8B200D010 ER8B2009727 8LBW0WMH

CANDELA DISTRIBUTION (FULL):

	0°
0°	10362.4
2.5°	10333.7
5°	10253.0
7.5°	10148.3
10°	10001.0
12.5°	9844.4
15°	9688.7
17.5°	9521.9
20°	9332.8
22.5°	9116.9
25°	8812.9
27.5°	8301.4
30°	7618.4
32.5°	6757.5
35°	5796.5
37.5°	4837.4
40°	3920.9
42.5°	3095.2
45°	2445.6
47.5°	1960.0
50°	1618.0
52.5°	1316.8
55°	1056.4
57.5°	853.5
60°	683.0
62.5°	540.3
65°	384.6
67.5°	228.9
70°	138.1
72.5°	77.8
75°	47.3
77.5°	30.6
80°	22.2
82.5°	7.4
85°	13.0
87.5°	5.6
90°	0.0

(END OF REPORT)