

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P244390

Luminaire Tested: **LD8B40D010 ER8B40835 8LBM0H**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P244390
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P27951)
Test Lab: INNOVATION CENTER-P2
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B40D010 ER8B40835 8LBM0H
Description: PORTFOLIO 8 INCH MEDIUM DISTRIBUTION 55 DEG CUTOFF RECESSED
DOWNLIGHT
80 CRI 3500 CCT WITH SEMI-SPECULAR CLEAR TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4337.0 lumens
Efficiency: N/A
Efficacy: 106.0 lumens/watt
Spacing Criteria (0/90/45): 0.91 / 0.91 / 0.93
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 40.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P244390

CATALOG NUMBER: LD8B40D010 ER8B40835 8LBM0H

Luminous Intensity Polar Plot





TEST NUMBER: P244390

CATALOG NUMBER: LD8B40D010 ER8B40835 8LBM0H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	113	110	108	105	111	108	106	104	104	102	100		100	99	97		97	96	95	93
2	107	102	98	94	105	100	96	93	97	94	91		94	91	89		91	89	87	85
3	101	94	89	85	99	93	88	84	90	86	83		88	84	82		86	83	80	79
4	96	88	82	77	94	86	81	77	84	80	76		82	78	75		80	77	74	73
5	90	82	75	71	89	81	75	70	79	74	70		77	73	69		75	72	69	67
6	85	76	70	65	84	75	69	65	74	68	64		72	68	64		71	67	64	62
7	81	71	65	60	80	70	64	60	69	64	60		68	63	59		67	62	59	58
8	77	67	60	56	75	66	60	56	65	59	56		64	59	55		63	58	55	54
9	73	63	56	52	72	62	56	52	61	56	52		60	55	52		59	55	51	50
10	69	59	53	49	68	58	53	49	58	52	48		57	52	48		56	51	48	47

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	140139
5°	134195
10°	122962
15°	114419
20°	107615
25°	100688
30°	87810
35°	63461
40°	35576
45°	20470
50°	12526
55°	7129
60°	3707
65°	1890
70°	1028
75°	620
80°	373
85°	354



TEST NUMBER: P244390

CATALOG NUMBER: LD8B40D010 ER8B40835 8LBM0H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	400.3	9.2
10°-20°	1007.5	23.2
20°-30°	1344.4	31.0
30°-40°	1036.2	23.9
40°-50°	386.4	8.9
50°-60°	126.4	2.9
60°-70°	29.1	0.7
70°-80°	5.9	0.1
80°-90°	0.8	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2752.2	63.5
0°-40°	3788.4	87.4
0°-60°	4301.1	99.2
0°-90°	4337.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4337.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4545	
5°	4335	400
15°	3584	1008
25°	2959	1344
35°	1686	1036
45°	469	386
55°	133	126
65°	26	29
75°	5	6
85°	1	1
90°	0	



TEST NUMBER: P244390

CATALOG NUMBER: LD8B40D010 ER8B40835 8LBM0H

CANDELA DISTRIBUTION (FULL):

0°	
0°	4544.6
1°	4524.9
2°	4491.8
3°	4449.3
4°	4397.5
5°	4335.3
6°	4264.8
7°	4184.0
8°	4098.0
9°	4008.9
10°	3927.0
11°	3848.3
12°	3774.7
13°	3707.4
14°	3645.2
15°	3584.1
16°	3521.9
17°	3461.8
18°	3399.6
19°	3338.5
20°	3279.4
21°	3218.3
22°	3159.3
23°	3097.1
24°	3031.8
25°	2959.3
26°	2879.5
27°	2791.4
28°	2694.0
29°	2585.2
30°	2466.1
32.5°	2116.9
35°	1685.8
37.5°	1248.6
40°	883.8
42.5°	633.1
45°	469.4
47.5°	353.3
50°	261.1
52.5°	186.5
55°	132.6
57.5°	91.2
60°	60.1
62.5°	39.4
65°	25.9



TEST NUMBER: P244390

CATALOG NUMBER: LD8B40D010 ER8B40835 8LBM0H

CANDELA DISTRIBUTION (continued):

	0°
67.5°	17.6
70°	11.4
72.5°	7.3
75°	5.2
77.5°	3.1
80°	2.1
82.5°	1.0
85°	1.0
87.5°	0.0
90°	0.0

(END OF REPORT)