

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P246292

Luminaire Tested: **LD8B40D010 ER8B40935 8LBW0B**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P246292
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-47)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B40D010 ER8B40935 8LBW0B
Description: PORTFOLIO 8 INCH WIDE DISTRIBUTION 60 DEGREE CUTOFF RECESSED
DOWNLIGHT
90 CRI 3500 CCT WITH SPECULAR BLACK TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2389.0 lumens
Efficiency: N/A
Efficacy: 58.4 lumens/watt
Spacing Criteria (0/90/45): 1.08 / 1.08 / 1.02
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 40.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P246292

CATALOG NUMBER: LD8B40D010 ER8B40935 8LBW0B

Luminous Intensity Polar Plot





TEST NUMBER: P246292

CATALOG NUMBER: LD8B40D010 ER8B40935 8LBW0B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	110	108	106	111	108	106	104	104	102	101	101	99	98	97	96	95	93
2	107	102	98	95	105	101	97	94	97	94	92	94	92	90	92	90	88	86
3	102	95	90	86	100	94	89	85	91	87	84	89	85	82	86	84	81	80
4	96	88	83	78	94	87	82	78	85	80	77	83	79	76	81	78	75	74
5	91	82	76	72	89	81	76	71	80	75	71	78	74	70	76	73	70	68
6	86	77	71	66	85	76	70	66	74	69	65	73	68	65	72	68	65	63
7	82	72	66	61	80	71	65	61	70	64	61	69	64	60	67	63	60	58
8	77	67	61	57	76	67	61	57	66	60	56	65	60	56	64	59	56	54
9	73	63	57	53	72	63	57	53	62	56	52	61	56	52	60	55	52	51
10	70	59	53	49	68	59	53	49	58	53	49	57	52	49	57	52	49	47

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	67365
5°	65672
10°	63923
15°	62734
20°	61102
25°	58937
30°	54076
35°	41461
40°	19728
45°	7509
50°	3665
55°	1500
60°	376
65°	88
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P246292

CATALOG NUMBER: LD8B40D010 ER8B40935 8LBW0B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	200.0	8.4
10°-20°	553.0	23.1
20°-30°	789.6	33.1
30°-40°	654.4	27.4
40°-50°	161.4	6.8
50°-60°	29.0	1.2
60°-70°	1.6	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1542.6	64.6
0°-40°	2197.0	92.0
0°-60°	2387.4	99.9
0°-90°	2389.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2389.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2185	
5°	2122	200
15°	1965	553
25°	1732	790
35°	1101	654
45°	172	161
55°	28	29
65°	1	2
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P246292

CATALOG NUMBER: LD8B40D010 ER8B40935 8LBW0B

CANDELA DISTRIBUTION (FULL):

	0°
0°	2184.6
2.5°	2166.4
5°	2121.6
7.5°	2077.9
10°	2041.5
12.5°	2006.3
15°	1965.1
17.5°	1916.6
20°	1862.0
22.5°	1800.1
25°	1732.2
27.5°	1640.0
30°	1518.7
32.5°	1347.7
35°	1101.4
37.5°	795.7
40°	490.1
42.5°	285.1
45°	172.2
47.5°	114.0
50°	76.4
52.5°	49.7
55°	27.9
57.5°	13.3
60°	6.1
62.5°	2.4
65°	1.2
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)