

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P244366

Luminaire Tested: **LD8B40D010 ER8B409727 8LBN0H**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P244366
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P27944)
Test Lab: INNOVATION CENTER-P2
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B40D010 ER8B409727 8LBN0H
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED
DOWNLIGHT
97 CRI 2700 CCT WITH SEMI-SPECULAR CLEAR TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2775.0 lumens
Efficiency: N/A
Efficacy: 67.8 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.79
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 40.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P244366

CATALOG NUMBER: LD8B40D010 ER8B409727 8LBN0H

Luminous Intensity Polar Plot





TEST NUMBER: P244366

CATALOG NUMBER: LD8B40D010 ER8B409727 8LBN0H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	111	109	106	111	109	107	105	105	103	101		101	100	98		98	97	96	94
2	108	104	100	96	106	102	98	95	99	96	93		96	93	91		93	91	89	88
3	103	97	92	88	101	95	91	87	93	89	86		90	87	85		88	86	83	82
4	98	91	85	81	96	90	85	81	87	83	80		85	82	79		84	80	78	76
5	93	85	79	75	92	84	79	75	82	78	74		81	77	74		79	76	73	72
6	89	80	74	70	87	79	74	70	78	73	69		76	72	69		75	71	69	67
7	85	76	70	66	83	75	69	65	74	69	65		72	68	65		71	67	64	63
8	81	71	66	62	79	71	65	61	70	65	61		69	64	61		68	64	61	59
9	77	68	62	58	76	67	62	58	66	61	58		65	61	58		64	60	57	56
10	74	64	59	55	73	64	58	55	63	58	55		62	58	54		61	57	54	53

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P244366

CATALOG NUMBER: LD8B40D010 ER8B409727 8LBN0H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	356.2	12.8
10°-20°	796.1	28.7
20°-30°	905.1	32.6
30°-40°	531.5	19.2
40°-50°	142.7	5.1
50°-60°	33.8	1.2
60°-70°	7.7	0.3
70°-80°	1.7	0.1
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2057.4	74.1
0°-40°	2588.9	93.3
0°-60°	2765.4	99.7
0°-90°	2775.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2775.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4236	
5°	3936	356
15°	2847	796
25°	1997	905
35°	828	532
45°	171	143
55°	34	34
65°	8	8
75°	2	2
85°	0	0
90°	0	



TEST NUMBER: P244366

CATALOG NUMBER: LD8B40D010 ER8B409727 8LBN0H

CANDELA DISTRIBUTION (FULL):

0°	
0°	4236.1
1°	4212.6
2°	4169.5
3°	4108.6
4°	4029.9
5°	3936.2
6°	3830.3
7°	3710.3
8°	3590.3
9°	3469.4
10°	3354.2
11°	3241.7
12°	3135.8
13°	3037.4
14°	2939.0
15°	2847.2
16°	2757.2
17°	2668.2
18°	2581.9
19°	2494.8
20°	2409.5
21°	2324.2
22°	2242.7
23°	2162.1
24°	2079.6
25°	1997.1
26°	1911.9
27°	1819.1
28°	1721.6
29°	1614.8
30°	1499.5
32.5°	1176.2
35°	827.5
37.5°	545.4
40°	357.1
42.5°	246.5
45°	170.6
47.5°	117.1
50°	77.8
52.5°	50.6
55°	33.7
57.5°	22.5
60°	15.0
62.5°	10.3
65°	7.5



TEST NUMBER: P244366

CATALOG NUMBER: LD8B40D010 ER8B409727 8LBN0H

CANDELA DISTRIBUTION (continued):

	0°
67.5°	4.7
70°	2.8
72.5°	1.9
75°	1.9
77.5°	0.9
80°	0.9
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)