

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P244948

Luminaire Tested: **LD8B40D010 ER8B409730 8LBS0WMH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P244948
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-14)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B40D010 ER8B409730 8LBS0WMH
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT
97 CRI 3000 CCT WITH WARM HAZE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3484.0 lumens
Efficiency: N/A
Efficacy: 85.2 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.25
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 40.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P244948

CATALOG NUMBER: LD8B40D010 ER8B409730 8LBS0WMH

Luminous Intensity Polar Plot






TEST NUMBER: P244948

CATALOG NUMBER: LD8B40D010 ER8B409730 8LBS0WMH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	112	109	106	103	110	107	104	101	102	100	98	99	97	95	95	94	92	91
2	105	99	94	89	102	97	92	88	94	90	86	90	87	85	88	85	83	81
3	98	90	83	78	95	88	82	78	85	80	76	83	79	75	80	77	74	72
4	91	82	75	69	89	80	74	69	78	72	68	76	71	67	74	70	66	65
5	85	74	67	62	83	73	67	61	71	65	61	70	64	60	68	63	60	58
6	79	68	61	55	77	67	60	55	66	59	55	64	58	54	63	58	54	52
7	74	63	55	50	72	62	55	50	60	54	49	59	53	49	58	53	49	47
8	69	58	50	45	68	57	50	45	56	49	45	55	49	45	54	48	45	43
9	65	53	46	41	64	53	46	41	52	45	41	51	45	41	50	45	41	39
10	61	50	43	38	60	49	42	38	48	42	38	47	42	38	46	41	37	36

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P244948

CATALOG NUMBER: LD8B40D010 ER8B409730 8LBS0WMH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	186.0	5.3
10°-20°	526.4	15.1
20°-30°	783.7	22.5
30°-40°	890.2	25.6
40°-50°	727.7	20.9
50°-60°	285.1	8.2
60°-70°	66.5	1.9
70°-80°	16.0	0.5
80°-90°	2.5	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1496.0	42.9
0°-40°	2386.2	68.5
0°-60°	3399.0	97.6
0°-90°	3484.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3484.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1975	
5°	1962	186
15°	1866	526
25°	1705	784
35°	1430	890
45°	966	728
55°	297	285
65°	62	66
75°	15	16
85°	2	3
90°	0	



TEST NUMBER: P244948

CATALOG NUMBER: LD8B40D010 ER8B409730 8LBS0WMH

CANDELA DISTRIBUTION (FULL):

	0°
0°	1975.4
2.5°	1972.2
5°	1961.8
7.5°	1943.9
10°	1921.9
12.5°	1894.7
15°	1866.4
17.5°	1832.9
20°	1796.2
22.5°	1753.2
25°	1705.0
27.5°	1648.4
30°	1584.5
32.5°	1512.2
35°	1430.4
37.5°	1340.3
40°	1239.7
42.5°	1118.2
45°	966.2
47.5°	788.1
50°	602.6
52.5°	432.8
55°	296.6
57.5°	193.9
60°	129.9
62.5°	89.1
65°	61.8
67.5°	40.9
70°	27.2
72.5°	18.9
75°	14.7
77.5°	10.5
80°	6.3
82.5°	3.1
85°	2.1
87.5°	1.0
90°	0.0

(END OF REPORT)