

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P243863

Luminaire Tested: **LD8B50D010 ER8B50927 8LBW0LI**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P243863
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P27941)
Test Lab: INNOVATION CENTER-P2
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B50D010 ER8B50927 8LBW0LI
Description: PORTFOLIO 8 INCH WIDE DISTRIBUTION 60 DEGREE CUTOFF RECESSED
DOWNLIGHT
97 CRI 2700 CCT WITH SPECULAR CLEAR TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4550.6 lumens
Efficiency: N/A
Efficacy: 85.9 lumens/watt
Spacing Criteria (0/90/45): 1.34 / 1.34 / 1.17
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 53
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P243863

CATALOG NUMBER: LD8B50D010 ER8B50927 8LBW0LI

Luminous Intensity Polar Plot





TEST NUMBER: P243863

CATALOG NUMBER: LD8B50D010 ER8B50927 8LBW0LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	113	110	107	105	110	108	105	103	104	102	100		100	98	97		96	95	94	92
2	106	101	97	93	104	99	95	92	96	93	90		93	90	88		90	88	86	84
3	100	93	87	83	98	92	86	82	89	85	81		86	83	80		84	81	78	77
4	94	86	79	75	92	84	79	74	82	77	73		80	76	72		78	75	72	70
5	88	79	72	68	87	78	72	67	76	71	67		74	70	66		73	69	65	64
6	83	73	66	62	82	72	66	61	71	65	61		69	64	60		68	63	60	58
7	78	68	61	56	77	67	61	56	66	60	56		64	59	55		63	59	55	54
8	74	63	56	52	72	62	56	52	61	55	51		60	55	51		59	54	51	49
9	70	59	52	48	68	58	52	47	57	51	47		56	51	47		55	50	47	45
10	66	55	48	44	65	54	48	44	53	48	44		53	47	44		52	47	43	42

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P243863

CATALOG NUMBER: LD8B50D010 ER8B50927 8LBW0LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	262.5	5.8
10°-20°	869.9	19.1
20°-30°	1368.7	30.1
30°-40°	1302.0	28.6
40°-50°	600.2	13.2
50°-60°	136.4	3.0
60°-70°	9.0	0.2
70°-80°	1.8	0.0
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2501.1	55.0
0°-40°	3803.1	83.6
0°-60°	4539.7	99.8
0°-90°	4550.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4550.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2618	
5°	2686	263
15°	3086	870
25°	3002	1369
35°	2134	1302
45°	734	600
55°	132	136
65°	6	9
75°	1	2
85°	0	0
90°	0	



TEST NUMBER: P243863

CATALOG NUMBER: LD8B50D010 ER8B50927 8LBW0LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	2618.3
1°	2617.1
2°	2622.0
3°	2637.0
4°	2659.4
5°	2685.5
6°	2717.9
7°	2752.8
8°	2788.9
9°	2831.2
10°	2876.1
11°	2920.8
12°	2968.1
13°	3013.0
14°	3054.0
15°	3086.4
16°	3110.1
17°	3126.3
18°	3133.7
19°	3132.5
20°	3123.8
21°	3108.8
22°	3090.2
23°	3065.3
24°	3036.6
25°	3001.7
26°	2960.7
27°	2908.4
28°	2846.1
29°	2773.9
30°	2690.5
32.5°	2440.2
35°	2134.0
37.5°	1778.0
40°	1389.5
42.5°	1027.1
45°	734.5
47.5°	520.4
50°	358.5
52.5°	229.0
55°	132.0
57.5°	66.0
60°	28.7
62.5°	11.2
65°	6.2



TEST NUMBER: P243863

CATALOG NUMBER: LD8B50D010 ER8B50927 8LBW0LI

CANDELA DISTRIBUTION (continued):

	0°
67.5°	3.7
70°	2.5
72.5°	2.5
75°	1.2
77.5°	1.2
80°	1.2
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)