

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P245801

Luminaire Tested: **LD8B50D010 ER8B50950 8LBS0GPH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P245801
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-16)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD8B50D010 ER8B50950 8LBS0GPH
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT
90 CRI 5000 CCT WITH GRAPHITE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5028.9 lumens
Efficiency: N/A
Efficacy: 94.9 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.25
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 53
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P245801

CATALOG NUMBER: LD8B50D010 ER8B50950 8LBS0GPH

Luminous Intensity Polar Plot





TEST NUMBER: P245801

CATALOG NUMBER: LD8B50D010 ER8B50950 8LBS0GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	109	106	103	110	107	104	102	103	100	98		99	97	95		95	94	93	91
2	105	99	94	90	103	97	93	89	94	90	87		91	88	85		88	85	83	81
3	98	90	84	79	96	88	83	78	86	81	77		83	79	76		81	77	74	73
4	91	82	75	70	89	81	74	69	78	73	69		76	72	68		74	70	67	65
5	85	75	68	62	83	74	67	62	72	66	61		70	65	61		68	64	60	58
6	79	69	61	56	78	68	61	56	66	60	55		64	59	55		63	58	54	53
7	74	63	56	50	73	62	55	50	61	55	50		59	54	50		58	53	49	48
8	70	58	51	46	68	57	50	46	56	50	45		55	49	45		54	49	45	43
9	65	54	47	42	64	53	46	42	52	46	41		51	45	41		50	45	41	40
10	62	50	43	38	60	49	43	38	48	42	38		48	42	38		47	42	38	36

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	89012
5°	88742
10°	87868
15°	86968
20°	86055
25°	84649
30°	82333
35°	78578
40°	73061
45°	61689
50°	41880
55°	21881
60°	9818
65°	4786
70°	1920
75°	1168
80°	870
85°	566



TEST NUMBER: P245801

CATALOG NUMBER: LD8B50D010 ER8B50950 8LBS0GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	271.7	5.4
10°-20°	768.4	15.3
20°-30°	1143.8	22.7
30°-40°	1300.3	25.9
40°-50°	1063.2	21.1
50°-60°	396.3	7.9
60°-70°	72.4	1.4
70°-80°	11.2	0.2
80°-90°	1.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2183.9	43.4
0°-40°	3484.2	69.3
0°-60°	4943.8	98.3
0°-90°	5028.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5028.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2887	
5°	2867	272
15°	2724	768
25°	2488	1144
35°	2087	1300
45°	1415	1063
55°	407	396
65°	66	72
75°	10	11
85°	2	2
90°	0	



TEST NUMBER: P245801

CATALOG NUMBER: LD8B50D010 ER8B50950 8LBS0GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	2886.6
2.5°	2881.7
5°	2866.9
7.5°	2840.7
10°	2806.2
12.5°	2766.8
15°	2724.2
17.5°	2674.9
20°	2622.4
22.5°	2560.1
25°	2487.9
27.5°	2405.8
30°	2312.3
32.5°	2205.6
35°	2087.4
37.5°	1961.1
40°	1815.0
42.5°	1634.5
45°	1414.6
47.5°	1150.4
50°	873.0
52.5°	615.4
55°	407.0
57.5°	256.0
60°	159.2
62.5°	101.7
65°	65.6
67.5°	37.7
70°	21.3
72.5°	13.1
75°	9.8
77.5°	6.6
80°	4.9
82.5°	1.6
85°	1.6
87.5°	0.0
90°	0.0

(END OF REPORT)