

Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P865922

Luminaire Tested: PRLX-2001-M-927-35L-L-U-S-X-X-GREY-X

Issue Date: 8/20/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P865922  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2304-993-48)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 8/20/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: Prenalux  
Catalog Number: PRLX-2001-M-927-35L-L-U-S-X-X-GREY-X  
Description: PRENTALUX 3D PRINTED PENDANT LED LUMINAIRE, MEDIUM LIGHT ENGINE, FLAT LENS,  
TAPERED DRUM WITH GRAY INTERIOR SHADE.  
LIGHT LEVEL 4  
Light Source: 2700K CCT, 90 CRI LEDS  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 2649.0 lumens  
Efficiency: N/A  
Efficacy: 88.3 lumens/watt  
Spacing Criteria (0/90/45): 1.15 / 1.15 / 1.27  
Luminous Opening: Circular (Dia: 1.27' x H: 0')  
CIE Type: Direct

Input Watts (W): 30  
Input Voltage (V): 120  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: 0.5 HR  
Operation Time: 3 HR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P865922

CATALOG NUMBER: PRLX-2001-M-927-35L-L-U-S-X-X-GREY-X

### Luminous Intensity Polar Plot





TEST NUMBER: P865922

CATALOG NUMBER: PRLX-2001-M-927-35L-L-U-S-X-X-GREY-X

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	112	108	105	102	109	106	103	100	102	99	97	98	96	94	94	93	91	90
2	104	97	92	87	101	95	91	86	92	88	85	89	86	83	86	83	81	79
3	96	88	81	76	94	86	80	75	83	78	74	81	76	73	78	75	71	70
4	89	79	72	66	87	78	71	66	76	70	65	73	68	64	71	67	63	61
5	83	72	64	58	81	71	63	58	69	62	57	67	61	57	65	60	56	55
6	77	65	57	52	75	64	57	52	63	56	51	61	55	51	60	54	50	49
7	72	60	52	46	70	59	52	46	57	51	46	56	50	46	55	49	45	44
8	67	55	47	42	65	54	47	42	53	46	42	52	46	41	51	45	41	39
9	63	50	43	38	61	50	43	38	49	42	38	48	42	38	47	41	37	36
10	59	47	39	35	58	46	39	35	45	39	34	44	39	34	44	38	34	33

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	11636
5°	11582
10°	11410
15°	11157
20°	10867
25°	10568
30°	10259
35°	9926
40°	9562
45°	9134
50°	8617
55°	6451
60°	2547
65°	695
70°	595
75°	639
80°	694
85°	691

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 9134 cd/sqm

TEST NUMBER: P865922

CATALOG NUMBER: PRLX-2001-M-927-35L-L-U-S-X-X-GREY-X

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	128.6	4.9
10°-20°	357.9	13.5
20°-30°	520.3	19.6
30°-40°	599.2	22.6
40°-50°	587.3	22.2
50°-60°	373.1	14.1
60°-70°	54.4	2.1
70°-80°	20.5	0.8
80°-90°	7.8	0.3
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1006.8	38.0
0°-40°	1606.0	60.6
0°-60°	2566.3	96.9
0°-90°	2649.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2649.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1371	
5°	1360	129
15°	1270	358
25°	1129	520
35°	958	599
45°	761	587
55°	436	373
65°	35	54
75°	20	21
85°	7	8
90°	0	

TEST NUMBER: P865922

CATALOG NUMBER: PRLX-2001-M-927-35L-L-U-S-X-X-GREY-X

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	1371.2
2.5°	1369.4
5°	1359.6
7.5°	1343.6
10°	1324.1
12.5°	1300.1
15°	1269.9
17.5°	1240.6
20°	1203.3
22.5°	1170.5
25°	1128.7
27.5°	1090.5
30°	1047.0
32.5°	1004.4
35°	958.2
37.5°	912.0
40°	863.2
42.5°	816.1
45°	761.1
47.5°	709.6
50°	652.7
52.5°	568.4
55°	436.0
57.5°	278.0
60°	150.1
62.5°	75.5
65°	34.6
67.5°	24.9
70°	24.0
72.5°	22.2
75°	19.5
77.5°	16.9
80°	14.2
82.5°	10.7
85°	7.1
87.5°	3.6
90°	0.0



TEST NUMBER: P865922  
 CATALOG NUMBER: PRLX-2001-M-927-35L-L-U-S-X-X-GREY-X

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.83	17.24	16.20	17.55	17.86	15.83	17.24	16.20	17.55	17.86
	3H	15.77	17.00	16.14	17.33	17.69	15.77	17.00	16.14	17.33	17.69
	4H	15.74	16.89	16.14	17.24	17.62	15.74	16.89	16.14	17.24	17.62
	6H	15.72	16.77	16.13	17.14	17.53	15.72	16.77	16.13	17.14	17.53
	8H	15.70	16.70	16.13	17.09	17.49	15.70	16.70	16.13	17.09	17.49
	12H	15.68	16.64	16.12	17.02	17.45	15.68	16.64	16.12	17.02	17.45
4H	2H	15.67	16.82	16.08	17.17	17.55	15.67	16.82	16.08	17.17	17.55
	3H	15.64	16.56	16.05	16.96	17.37	15.64	16.56	16.05	16.96	17.37
	4H	15.62	16.45	16.06	16.86	17.31	15.62	16.45	16.06	16.86	17.31
	6H	15.64	16.34	16.10	16.79	17.26	15.64	16.34	16.10	16.79	17.26
	8H	15.63	16.29	16.09	16.73	17.20	15.63	16.29	16.09	16.73	17.20
	12H	15.62	16.21	16.10	16.69	17.16	15.62	16.21	16.10	16.69	17.16
8H	4H	15.53	16.19	16.00	16.64	17.11	15.53	16.19	16.00	16.64	17.11
	6H	15.55	16.10	16.05	16.60	17.08	15.55	16.10	16.05	16.60	17.08
	8H	15.55	16.05	16.07	16.57	17.06	15.55	16.05	16.07	16.57	17.06
	12H	15.57	16.02	16.08	16.51	17.08	15.57	16.02	16.08	16.51	17.08
12H	4H	15.49	16.08	15.98	16.57	17.04	15.49	16.08	15.98	16.57	17.04
	6H	15.51	16.00	16.03	16.52	17.01	15.51	16.00	16.03	16.52	17.01
	8H	15.53	15.98	16.05	16.48	17.05	15.53	15.98	16.05	16.48	17.05