

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P865524

Luminaire Tested: PRLX-2001-S-935-25L-G-U-S-X-X-BLAK-X

Issue Date: 8/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P865524
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2304-993-6)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 8/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: Prenalux
Catalog Number: PRLX-2001-S-935-25L-G-U-S-X-X-BLAK-X
Description: PRENTALUX 3D PRINTED PENDANT LED LUMINAIRE, SMALL LIGHT ENGINE, GLOBE LENS,
TAPERED DRUM WITH BLACK INTERIOR SHADE.
LIGHT LEVEL 5
Light Source: 3500K CCT, 90 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 760.1 lumens
Efficiency: N/A
Efficacy: 26.1 lumens/watt
Spacing Criteria (0/90/45): 1.52 / 1.52 / 1.69
Luminous Opening: Circular (Dia: 0.92' x H: 0')
CIE Type: Direct

Input Watts (W): 29.1
Input Voltage (V): 120
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: 0.5 HR
Operation Time: 3 HR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P865524

CATALOG NUMBER: PRLX-2001-S-935-25L-G-U-S-X-X-BLAK-X

Luminous Intensity Polar Plot





TEST NUMBER: P865524

CATALOG NUMBER: PRLX-2001-S-935-25L-G-U-S-X-X-BLAK-X

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	107	102	97	92	104	99	95	91	95	91	88		91	88	85		87	85	82	80
2	96	87	79	73	93	85	78	72	81	75	70		78	73	68		75	71	67	64
3	87	75	66	59	84	73	65	58	70	63	57		67	61	56		65	60	55	53
4	79	66	56	49	76	64	55	48	62	54	47		59	52	47		57	51	46	44
5	72	58	48	41	70	57	48	41	55	46	40		53	45	40		51	44	39	37
6	66	52	42	35	64	51	42	35	49	41	35		47	40	34		45	39	34	32
7	61	46	37	30	59	46	37	30	44	36	30		43	35	30		41	35	30	27
8	57	42	33	27	55	41	33	27	40	32	27		39	32	26		37	31	26	24
9	53	38	30	24	51	38	29	24	37	29	24		35	28	23		34	28	23	21
10	49	35	27	21	48	35	27	21	34	26	21		33	26	21		32	25	21	19

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2952
5°	2970
10°	3027
15°	3090
20°	3168
25°	3265
30°	3399
35°	3572
40°	3790
45°	4076
50°	4352
55°	4496
60°	4544
65°	4523
70°	4478
75°	4392
80°	4358
85°	4828

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 87.5°
 Luminance: 6244 cd/sqm

TEST NUMBER: P865524

CATALOG NUMBER: PRLX-2001-S-935-25L-G-U-S-X-X-BLAK-X

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	17.4	2.3
10°-20°	51.8	6.8
20°-30°	84.0	11.1
30°-40°	112.6	14.8
40°-50°	136.2	17.9
50°-60°	140.7	18.5
60°-70°	115.9	15.2
70°-80°	73.8	9.7
80°-90°	27.7	3.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	153.2	20.2
0°-40°	265.9	35.0
0°-60°	542.7	71.4
0°-90°	760.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	760.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	181	
5°	181	17
15°	183	52
25°	181	84
35°	179	113
45°	177	136
55°	158	141
65°	117	116
75°	70	74
85°	26	28
90°	0	

TEST NUMBER: P865524

CATALOG NUMBER: PRLX-2001-S-935-25L-G-U-S-X-X-BLAK-X

CANDELA DISTRIBUTION (FULL):

	0°
0°	181.0
2.5°	181.0
5°	181.4
7.5°	182.3
10°	182.8
12.5°	183.2
15°	183.0
17.5°	182.8
20°	182.5
22.5°	182.3
25°	181.4
27.5°	181.2
30°	180.5
32.5°	180.0
35°	179.4
37.5°	178.7
40°	178.0
42.5°	177.6
45°	176.7
47.5°	174.8
50°	171.5
52.5°	165.8
55°	158.1
57.5°	149.1
60°	139.3
62.5°	128.5
65°	117.2
67.5°	105.9
70°	93.9
72.5°	81.7
75°	69.7
77.5°	58.1
80°	46.4
82.5°	36.0
85°	25.8
87.5°	16.7
90°	0.0



TEST NUMBER: P865524
 CATALOG NUMBER: PRLX-2001-S-935-25L-G-U-S-X-X-BLAK-X

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	17.85	19.62	18.22	19.93	20.25	17.85	19.62	18.22	19.93	20.25
	3H	19.93	21.55	20.31	21.87	22.23	19.93	21.55	20.31	21.87	22.23
	4H	20.77	22.29	21.16	22.64	23.01	20.77	22.29	21.16	22.64	23.01
	6H	21.46	22.88	21.87	23.24	23.63	21.46	22.88	21.87	23.24	23.63
	8H	21.73	23.09	22.15	23.48	23.88	21.73	23.09	22.15	23.48	23.88
	12H	21.97	23.28	22.40	23.66	24.09	21.97	23.28	22.40	23.66	24.09
4H	2H	18.58	20.11	18.97	20.45	20.82	18.58	20.11	18.97	20.45	20.82
	3H	20.89	22.18	21.29	22.58	22.98	20.89	22.18	21.29	22.58	22.98
	4H	21.86	23.04	22.29	23.45	23.89	21.86	23.04	22.29	23.45	23.89
	6H	22.71	23.75	23.15	24.18	24.63	22.71	23.75	23.15	24.18	24.63
	8H	23.05	24.03	23.50	24.47	24.93	23.05	24.03	23.50	24.47	24.93
	12H	23.36	24.25	23.84	24.72	25.18	23.36	24.25	23.84	24.72	25.18
8H	4H	22.27	23.25	22.73	23.69	24.15	22.27	23.25	22.73	23.69	24.15
	6H	23.27	24.10	23.76	24.58	25.05	23.27	24.10	23.76	24.58	25.05
	8H	23.72	24.46	24.22	24.96	25.45	23.72	24.46	24.22	24.96	25.45
	12H	24.16	24.81	24.66	25.30	25.85	24.16	24.81	24.66	25.30	25.85
12H	4H	22.34	23.23	22.82	23.70	24.16	22.34	23.23	22.82	23.70	24.16
	6H	23.38	24.12	23.88	24.62	25.10	23.38	24.12	23.88	24.62	25.10
	8H	23.91	24.57	24.41	25.05	25.61	23.91	24.57	24.41	25.05	25.61