

Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P867230

Luminaire Tested: PRLX-2004-L-927-83L-L-X-X-GREY-X

Issue Date: 8/20/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P867230  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2304-993-86)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 8/20/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: Prenalux  
Catalog Number: PRLX-2004-L-927-83L-L-X-X-GREY-X  
Description: PRENATALUX 3D PRINTED PENDANT LED LUMINAIRE, LARGE LIGHT ENGINE, FLAT LENS, BELL WITH GRAY INTERIOR SHADE.  
LIGHT LEVEL 5  
Light Source: 2700K CCT, 90 CRI LEDS  
Ballast/Driver: -


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3924.3 lumens  
Efficiency: N/A  
Efficacy: 60.8 lumens/watt  
Spacing Criteria (0/90/45): 1.02 / 1.02 / 0.98  
Luminous Opening: Circular (Dia: 1.67' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 64.5  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: 0.333 HR  
Operation Time: 3 HR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P867230

CATALOG NUMBER: PRLX-2004-L-927-83L-L-X-X-GREY-X

### Luminous Intensity Polar Plot





TEST NUMBER: P867230

CATALOG NUMBER: PRLX-2004-L-927-83L-L-X-X-GREY-X

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	110	107	104	110	108	105	103	103	101	100	100	98	97	96	95	94	92
2	107	101	97	93	104	99	95	92	96	93	90	93	90	88	90	88	86	84
3	101	94	88	84	99	92	87	83	89	85	82	87	83	80	85	82	79	77
4	95	87	81	76	93	86	80	76	83	79	75	81	77	74	79	76	73	71
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66
6	85	75	69	64	83	74	68	64	73	68	64	71	67	63	70	66	63	61
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57
8	76	66	60	55	75	65	59	55	64	59	55	63	58	55	62	58	54	53
9	72	62	56	51	71	62	55	51	61	55	51	60	55	51	59	54	51	49
10	69	58	52	48	68	58	52	48	57	52	48	56	51	48	56	51	48	46

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	18568
5°	17964
10°	17023
15°	16285
20°	15638
25°	15028
30°	14349
35°	10052
40°	3163
45°	1534
50°	1144
55°	1104
60°	1028
65°	951
70°	887
75°	827
80°	779
85°	719

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 1534 cd/sqm

TEST NUMBER: P867230

CATALOG NUMBER: PRLX-2004-L-927-83L-L-X-X-GREY-X

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	338.8	8.6
10°-20°	898.0	22.9
20°-30°	1270.1	32.4
30°-40°	967.2	24.6
40°-50°	194.4	5.0
50°-60°	114.0	2.9
60°-70°	81.1	2.1
70°-80°	46.2	1.2
80°-90°	14.3	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2507.0	63.9
0°-40°	3474.2	88.5
0°-60°	3782.6	96.4
0°-90°	3924.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3924.3	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3763	
5°	3627	339
15°	3188	898
25°	2761	1270
35°	1669	967
45°	220	194
55°	128	114
65°	82	81
75°	43	46
85°	13	14
90°	0	

TEST NUMBER: P867230

CATALOG NUMBER: PRLX-2004-L-927-83L-L-X-X-GREY-X

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	3763.4
2.5°	3735.3
5°	3627.1
7.5°	3505.5
10°	3397.9
12.5°	3294.4
15°	3188.2
17.5°	3086.6
20°	2978.4
22.5°	2868.8
25°	2760.6
27.5°	2651.0
30°	2518.7
32.5°	2238.8
35°	1668.9
37.5°	922.6
40°	491.1
42.5°	324.7
45°	219.8
47.5°	158.3
50°	149.0
52.5°	139.6
55°	128.3
57.5°	115.6
60°	104.2
62.5°	92.2
65°	81.5
67.5°	71.5
70°	61.5
72.5°	52.1
75°	43.4
77.5°	35.4
80°	27.4
82.5°	20.0
85°	12.7
87.5°	6.0
90°	0.0



TEST NUMBER: P867230  
 CATALOG NUMBER: PRLX-2004-L-927-83L-L-X-X-GREY-X

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	7.12	8.17	7.49	8.49	8.80	7.12	8.17	7.49	8.49	8.80
	3H	8.69	9.62	9.07	9.95	10.32	8.69	9.62	9.07	9.95	10.32
	4H	9.28	10.14	9.68	10.49	10.88	9.28	10.14	9.68	10.49	10.88
	6H	9.73	10.52	10.15	10.90	11.29	9.73	10.52	10.15	10.90	11.29
	8H	9.89	10.63	10.32	11.02	11.43	9.89	10.63	10.32	11.02	11.43
	12H	9.99	10.70	10.42	11.08	11.51	9.99	10.70	10.42	11.08	11.51
4H	2H	7.59	8.45	7.99	8.80	9.19	7.59	8.45	7.99	8.80	9.19
	3H	9.36	10.07	9.78	10.48	10.88	9.36	10.07	9.78	10.48	10.88
	4H	10.07	10.71	10.51	11.13	11.58	10.07	10.71	10.51	11.13	11.58
	6H	10.66	11.20	11.13	11.65	12.13	10.66	11.20	11.13	11.65	12.13
	8H	10.86	11.37	11.34	11.82	12.29	10.86	11.37	11.34	11.82	12.29
	12H	11.01	11.45	11.50	11.93	12.41	11.01	11.45	11.50	11.93	12.41
8H	4H	10.30	10.80	10.77	11.25	11.72	10.30	10.80	10.77	11.25	11.72
	6H	11.02	11.42	11.53	11.93	12.41	11.02	11.42	11.53	11.93	12.41
	8H	11.31	11.67	11.84	12.19	12.68	11.31	11.67	11.84	12.19	12.68
	12H	11.55	11.86	12.07	12.35	12.93	11.55	11.86	12.07	12.35	12.93
12H	4H	10.30	10.74	10.79	11.22	11.70	10.30	10.74	10.79	11.22	11.70
	6H	11.06	11.42	11.59	11.94	12.43	11.06	11.42	11.59	11.94	12.43
	8H	11.41	11.72	11.93	12.22	12.79	11.41	11.72	11.93	12.22	12.79