

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P735825

Luminaire Tested: PRLX-UHBS-2436-MV-L84050-CLER(5000K_L36_347V)

Issue Date: 1/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P735825
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2312-243-2)
Test Lab: INNOVATION CENTER
Issue Date: 1/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS-2436-MV-L84050-CLER(5000K_L36_347V)
Description: PRENTALUX LARGE HIGH BAY LUMINAIRE WITH CLEAR SHADE
LIGHT LEVEL 3 - 36,0000 NOMINAL LUMENS
Light Source: 5000K CCT, 80 CRI LEDS
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 35785.8 lumens
Efficiency: N/A
Efficacy: 156.4 lumens/watt
Spacing Criteria (0/90/45): 1.39 / 1.39 / 1.46
Luminous Opening: Vertical Cylinder (Dia: 1.71' x H: 1.04')
CIE Type: Direct

Input Watts (W): 228.8
Input Voltage (V): 347
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P735825

CATALOG NUMBER: PRLX-UHBS-2436-MV-L84050-CLER(5000K_L36_347V)

Luminous Intensity Polar Plot





TEST NUMBER: P735825

CATALOG NUMBER: PRLX-UHBS-2436-MV-L84050-CLER(5000K_L36_347V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97		
1	110	106	103	100	107	104	101	98	99	97	94	95	93	91	91	89	88	86		
2	102	95	90	85	99	93	88	84	89	85	81	86	82	79	82	79	77	75		
3	94	85	78	73	92	84	77	72	80	75	70	77	73	69	74	71	67	65		
4	87	77	69	63	85	75	68	63	72	66	61	70	65	60	67	63	59	57		
5	81	69	61	55	78	68	60	55	65	59	54	63	58	53	61	56	52	50		
6	75	63	55	49	73	62	54	48	59	53	48	58	52	47	56	51	47	45		
7	69	57	49	43	68	56	48	43	54	48	43	53	47	42	51	46	42	40		
8	65	52	44	39	63	51	44	39	50	43	38	48	42	38	47	42	37	36		
9	60	48	40	35	59	47	40	35	46	39	35	45	39	34	43	38	34	32		
10	57	44	37	32	55	44	36	32	42	36	31	41	35	31	40	35	31	29		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	64075
5°	60527
10°	58449
15°	57548
20°	56346
25°	55179
30°	51543
35°	45597
40°	40636
45°	38286
50°	35371
55°	21955
60°	9586
65°	4645
70°	2644
75°	1722
80°	1352
85°	1168

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 38286 cd/sqm

TEST NUMBER: P735825

CATALOG NUMBER: PRLX-UHBS-2436-MV-L84050-CLER(5000K_L36_347V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1315.8	3.7
10°-20°	4049.5	11.3
20°-30°	6640.6	18.6
30°-40°	7701.6	21.5
40°-50°	7893.3	22.1
50°-60°	5126.9	14.3
60°-70°	1232.7	3.4
70°-80°	416.5	1.2
80°-90°	236.1	0.7
90°-100°	175.7	0.5
100°-110°	201.7	0.6
110°-120°	372.2	1.0
120°-130°	202.0	0.6
130°-140°	68.8	0.2
140°-150°	62.7	0.2
150°-160°	59.9	0.2
160°-170°	24.8	0.1
170°-180°	5.1	0.0
0°-30°	12005.9	33.5
0°-40°	19707.4	55.1
0°-60°	32727.6	91.5
0°-90°	34612.9	96.7
90°-120°	749.6	2.1
90°-150°	1083.1	3.0
90°-180°	1173.0	3.3
0°-180°	35785.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	13644	
5°	13712	###
15°	14299	4049
25°	14504	6641
35°	12277	7702
45°	10240	7893
55°	5655	5127
65°	1114	1233
75°	370	416
85°	214	186
90°	168	95
95°	157	131
105°	179	202
115°	449	372
125°	221	202
135°	79	69
145°	101	63
155°	133	60
165°	85	25
175°	50	5
180°	50	

TEST NUMBER: P735825

CATALOG NUMBER: PRLX-UHBS-2436-MV-L84050-CLER(5000K_L36_347V)

CANDELA DISTRIBUTION (FULL):

0°	
0°	13644.4
2.5°	13650.1
5°	13712.0
7.5°	13802.4
10°	13935.2
12.5°	14131.0
15°	14299.3
17.5°	14404.7
20°	14460.8
22.5°	14494.0
25°	14504.3
27.5°	14338.3
30°	13765.8
32.5°	13031.9
35°	12277.3
37.5°	11594.9
40°	10946.9
42.5°	10505.0
45°	10240.5
47.5°	9965.7
50°	9321.1
52.5°	7801.7
55°	5654.9
57.5°	3825.3
60°	2393.0
62.5°	1588.1
65°	1114.0
67.5°	810.6
70°	603.4
72.5°	461.4
75°	369.8
77.5°	311.4
80°	270.2
82.5°	238.2
85°	214.1
87.5°	194.6
90°	168.3
92.5°	160.3
95°	156.9
97.5°	159.1
100°	167.2
102.5°	172.9
105°	178.6
107.5°	201.5
110°	254.2

TEST NUMBER: P735825

CATALOG NUMBER: PRLX-UHBS-2436-MV-L84050-CLER(5000K_L36_347V)

CANDELA DISTRIBUTION (continued):

	0°
112.5°	351.5
115°	448.8
117.5°	413.3
120°	322.9
122.5°	267.9
125°	221.0
127.5°	176.3
130°	134.0
132.5°	100.8
135°	79.0
137.5°	69.8
140°	71.0
142.5°	82.4
145°	100.8
147.5°	119.1
150°	132.8
152.5°	136.2
155°	132.8
157.5°	123.7
160°	112.2
162.5°	98.5
165°	84.7
167.5°	71.0
170°	58.4
172.5°	52.7
175°	50.4
177.5°	50.4
180°	50.4

(END OF REPORT)